

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER DSD 150T 7857618 (S/N 1060)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Feb2022	Sep 2022		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP49339	KCP48562	
Sample Date		Client Info		30 Sep 2022	08 Feb 2022	
Machine Age	hrs	Client Info		8673	3203	
Oil Age	hrs	Client Info		5400	3030	
Oil Changed	1113	Client Info		Changed	Changed	
Sample Status		Olletti IIIIO		ATTENTION	NORMAL	
			11 11 11			
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	<1	<1	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	0	0	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	0	30	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	18042	14500	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		1	0	
Potassium	ppm	ASTM D5185m	>20	0	<1	
Water	%	ASTM D6304	>0.05	0.007	0.001	
ppm Water	ppm	ASTM D6304	>500	75.9	12.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		5121	231	
Particles >6µm		ASTM D7647	>1300	1910	33	
Particles >14µm		ASTM D7647	>80	4 91	3	
Particles >21µm		ASTM D7647	>20	2 9	0	
Particles >38μm		ASTM D7647	>4	2	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/14	12/9	
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2

Acid Number (AN)


mg KOH/g ASTM D8045 1.0

0.54

0.55



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KCP49339 : 05656832

Recieved : 10156384

: 03 Oct 2022 Diagnosed : 05 Oct 2022 Diagnostician : Doug Bogart

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

111 GRELL LN JOHNSON CREEK, WI US 53038

Contact: KAREN G

KARENG@MASTERMOLDLLC.COM T:

Contact/Location: KAREN G - MASJOH

F: