




# OIL ANALYSIS REPORT

Sample Rating Trend

**WEAR**



Area  
**GUAY SON [CONHER]**  
 Machine Id  
**BM NAINARI IBACO BM NAINARI**  
 Component  
**Transmission (Manual)**  
 Fluid  
**Raloy SAE 50 (60 LTR)**



## DIAGNOSIS

- Recommendation**  
No corrective action is recommended at this time. Resample at the next service interval to monitor.
- Wear**  
The copper level is abnormal. All other component wear rates are normal.
- Contamination**  
There is a high amount of particulates present in the fluid.
- Fluid Condition**  
The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history 1	history 2
Sample Number	Client Info			<b>KL0010132</b>	KL0009159	---
Sample Date	Client Info			<b>03 Oct 2022</b>	23 Mar 2022	---
Machine Age	hrs	Client Info		<b>16699</b>	13882	---
Oil Age	hrs	Client Info		<b>180</b>	1302	---
Oil Changed	Client Info			<b>Not Chngd</b>	N/A	---
Sample Status				<b>ABNORMAL</b>	ABNORMAL	---

WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>200	<b>7</b>	7	---
Chromium	ppm	ASTM D5185m	>5	<b>&lt;1</b>	0	---
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m		<b>0</b>	0	---
Silver	ppm	ASTM D5185m	>7	<b>&lt;1</b>	<1	---
Aluminum	ppm	ASTM D5185m	>25	<b>1</b>	<1	---
Lead	ppm	ASTM D5185m	>45	<b>&lt;1</b>	0	---
Copper	ppm	ASTM D5185m	>225	<b>▲ 264</b>	132	---
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	---
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	---

ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Barium	ppm	ASTM D5185m		<b>2</b>	0	---
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	<1	---
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	---
Magnesium	ppm	ASTM D5185m		<b>10</b>	6	---
Calcium	ppm	ASTM D5185m		<b>3251</b>	3585	---
Phosphorus	ppm	ASTM D5185m		<b>867</b>	942	---
Zinc	ppm	ASTM D5185m		<b>692</b>	685	---
Sulfur	ppm	ASTM D5185m		<b>6101</b>	4407	---

CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>125	<b>6</b>	6	---
Sodium	ppm	ASTM D5185m		<b>2</b>	5	---
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	---

FLUID CLEANLINESS		method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		<b>30854</b>	110690	---
Particles >6µm		ASTM D7647	>2500	<b>1897</b>	<b>▲ 6002</b>	---
Particles >14µm		ASTM D7647	>320	<b>106</b>	107	---
Particles >21µm		ASTM D7647	>80	<b>13</b>	15	---
Particles >38µm		ASTM D7647	>20	<b>1</b>	0	---
Particles >71µm		ASTM D7647	>4	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>18/15	<b>18/14</b>	<b>▲ 20/14</b>	---

FLUID DEGRADATION		method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.34</b>	0.939	---




# OIL ANALYSIS REPORT











VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	225	221	---

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KL0010132 **Received** : 10 Oct 2022  
**Lab Number** : 05662296 **Diagnosed** : 13 Oct 2022  
**Unique Number** : 10166865 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

JUAREZ 348  
 HERMOSILLO,  
 MX 83140  
 Contact: EDUARDO GARCIA  
 egarcia.comsa@gmail.com  
 T: (526)622-1581 x:81  
 F: x: