

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO

Machine Id


# KAESER SM 10 4679506 (S/N 1360)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

#### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ABNORMAL	ABNORMAL						
Particles >6µm	ASTM D7647	>1300	<b>5944</b>	<b>4</b> 9969						
Particles >14µm	ASTM D7647	>80	<u> </u>	<u></u> 748						
Particles >21µm	ASTM D7647	>20	<b>139</b>	<u></u> 169						
Particles >38µm	ASTM D7647	>4	<u> </u>	5						
Particles >71µm	ASTM D7647	>3	<u>^</u> 2	0						
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>21/20/16</b>	A 20/17						

Customer Id: RGHKAN Sample No.: KCP50147 Lab Number: 05664190 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Oil and filter change at the time of sampling has been noted.			
Change Filter			?	Oil and filter change at the time of sampling has been noted.			

### HISTORICAL DIAGNOSIS

31 May 2019 Diag: Angela Borella

ISC



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend

ISO

# KAESER SM 10 4679506 (S/N 1360)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			May2019	Sep 2022		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP50147	KCP18092	
Sample Date		Client Info		21 Sep 2022	31 May 2019	
Machine Age	hrs	Client Info		13957	2723	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1115	Client Info		Changed	Changed	
Sample Status		Ciletit iiiio		ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
			>50		2	
Iron Chromium	ppm	ASTM D5185m	>10	<1 0	0	
Nickel	ppm	ASTM D5185m		0		
	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	-	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m ASTM D5185m	>10	<1 0	<1	
Lead	ppm			2	<1 7	
Copper	ppm	ASTM D5185m ASTM D5185m	>50	_		
Tin	ppm		>10	0	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	2	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	44	28	
Calcium	ppm	ASTM D5185m	0	0	1	
Phosphorus	ppm	ASTM D5185m	0	10	3	
Zinc	ppm	ASTM D5185m	0	64	30	
Sulfur	ppm	ASTM D5185m	23500	19910	23737	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	
Sodium	ppm	ASTM D5185m		12	12	
Potassium	ppm	ASTM D5185m	>20	3	1	
Water	%	ASTM D6304	>0.05	0.021	0.021	
ppm Water	ppm	ASTM D6304	>500	219.9	210	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		16648	33441	
Particles >6µm		ASTM D7647	>1300	<b>5944</b>	<b>4</b> 9969	
Particles >14µm		ASTM D7647	>80	<u>^</u> 572	<b>▲</b> 748	
Particles >21µm		ASTM D7647	>20	<u> </u>	<b>169</b>	
Particles >38µm		ASTM D7647	>4	<u> </u>	5	
Particles >71µm		ASTM D7647	>3	<u>^</u> 2	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>21/20/16</b>	△ 20/17	



## **OIL ANALYSIS REPORT**







Sample No. Lab Number **Unique Number** 

: KCP50147 : 05664190 : 10168759

Received : 11 Oct 2022 Diagnosed

: 13 Oct 2022 Diagnostician : Jonathan Hester

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

12600 NE 40TH ST, SUITE 100 KANSAS CITY, MO

US 64161

Contact: CHRISTOPHER MORALES CHRISTOPHER.MORALES@JLC.OM

> T: F:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)