




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
KAESER AS 20T 4444102 (S/N 1034)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCP46017	KCP33591	KCP31772
Sample Date	Client Info			05 Oct 2022	30 Jun 2021	08 Oct 2020
Machine Age	hrs	Client Info		6952	77000	70898
Oil Age	hrs	Client Info		3000	3000	2587
Oil Changed	Client Info			Changed	Changed	Changed
Sample Status				ABNORMAL	SEVERE	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	0	2	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	7	7	4
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m		---	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	12
Barium	ppm	ASTM D5185m	90	1	<1	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	<1	0	1
Calcium	ppm	ASTM D5185m	0	0	<1	<1
Phosphorus	ppm	ASTM D5185m	0	6	8	2
Zinc	ppm	ASTM D5185m	0	0	0	14
Sulfur	ppm	ASTM D5185m	23500	14217	15769	16161

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	1
Sodium	ppm	ASTM D5185m		0	0	2
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.05	0.007	▲ 0.184	0.006
ppm Water	ppm	ASTM D6304	>500	71.8	▲ 1840	65.7

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2807	---	28972
Particles >6µm		ASTM D7647	>1300	1009	---	▲ 10799
Particles >14µm		ASTM D7647	>80	▲ 174	---	▲ 1994
Particles >21µm		ASTM D7647	>20	▲ 57	---	▲ 867
Particles >38µm		ASTM D7647	>4	3	---	▲ 49
Particles >71µm		ASTM D7647	>3	0	---	2
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ 19/17/15	---	▲ 21/18

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.58	0.437	0.448

OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	◆ >10%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	50.5	47.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP46017 **Received** : 20 Oct 2022
Lab Number : **05672306** **Tested** : 21 Oct 2022
Unique Number : 10181876 **Diagnosed** : 22 Oct 2022 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

CARMAX 7264
 7180 N PALM AVE
 FRESNO, CA
 US 93650
 Contact: Service Manager
 165749@carmax.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)