

PROBLEM SUMMARY

Sample Rating Trend

ISO


KAESER 6682696

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		ATTENTION	ABNORMAL						
Particles >6µm	ASTM D7647 >1300	<u> </u>	<u>^</u> 2208						
Particles >14µm	ASTM D7647 >80	<u> </u>	<u>^</u> 210						
Oil Cleanliness	ISO 4406 (c) >/17/13	19/18/14	<u>▲</u> 18/15						

Customer Id: HENSPA Sample No.: KCP46642D Lab Number: 05675670 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Oil and filter change at the time of sampling has been noted.			
Change Filter			?	Oil and filter change at the time of sampling has been noted.			

HISTORICAL DIAGNOSIS

16 Sep 2021 Diag: Don Baldridge






No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



KAESER 6682696

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Sep2021	0ct2022		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info	minu bass	KCP46642D	KCP42789	motory
Sample Date		Client Info		12 Oct 2022	16 Sep 2021	
Machine Age	hrs	Client Info		17036	13139	
	hrs	Client Info		0	0	
Oil Age	IIIS			-		
Oil Changed		Client Info		Changed	Changed	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	<1	2	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	11	3	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	0	53	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	25	47	
Calcium	ppm	ASTM D5185m	0	0	2	
Phosphorus	ppm	ASTM D5185m	0	0	3	
Zinc	ppm	ASTM D5185m	0	8	0	
Sulfur	ppm	ASTM D5185m	23500	21371	17330	
CONTAMINANTS		method	limit/base	current	history1	history2
						HISTOLYZ
Silicon	ppm	ASTM D5185m		5	4	
Sodium		ASTM D5185m		5	10	
Potassium	ppm	ASTM D5185m	>20	2	2	
Water	%	ASTM D6304	>0.05	0.018	0.019	
ppm Water	ppm	ASTM D6304	>500	182.9	196.7	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4341	6185	
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>^</u> 2208	
Particles >14μm		ASTM D7647	>80	<u> </u>	<u>^</u> 210	
Particles >21µm		ASTM D7647	>20	18	<u>▲</u> 61	
Particles >38µm		ASTM D7647	>4	1	4	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/18/14	<u>▲</u> 18/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.330

0.33



OIL ANALYSIS REPORT





Sample No. Lab Number **Unique Number**

: KCP46642D

: 05675670 : 10190241

Received : 25 Oct 2022 Diagnosed

: 27 Oct 2022 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

255 VISTA BLVD SPARKS, NV US 89431

Contact: MATTHEW MAK

matthew.mak@henryschein.com T:

F: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: MATTHEW MAK - HENSPA