


# **PROBLEM SUMMARY**

Machine Id KAESER AS 25T 3478474 (S/N 1492)

Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

# COMPONENT CONDITION SUMMARY



# RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

# Sample Rating Trend ISO

PROBLEMATIC TEST RESULTS						
Sample Status		ABNORM	AL NORMAL	ABNORMAL		
Particles >6µm	ASTM D7647 >	>1300 🔺 5006	542	▲ 5313		
Particles >14µm	ASTM D7647 >	>80 🔺 <b>872</b>	57	<b>1237</b>		
Particles >21µm	ASTM D7647 >	>20 🔺 186	20	463		
Particles >38µm	ASTM D7647 >	>4 🔺 7	1	<u> </u>		
Oil Cleanliness	ISO 4406 (c) >	/17/13 🔺 21/20/	<b>17</b> 16/13	<b>2</b> 0/17		

Customer Id: SOUBIRKC Sample No.: KCP46776D Lab Number: 05681190 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

# HISTORICAL DIAGNOSIS



# 04 Aug 2021 Diag: Don Baldridge

Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

# 17 Aug 2017 Diag: Don Baldridge



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

# 18 Sep 2015 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.









# **OIL ANALYSIS REPORT**

### Machine Id KAESER AS 25T 3478474 (S/N 1492) Component

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

# DIAGNOSIS

# Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

# Wear


All component wear rates are normal.

# Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP46776D	KCP37538	KCP01466
Sample Date		Client Info		25 Oct 2022	04 Aug 2021	17 Aug 2017
Machine Age	hrs	Client Info		23942	21555	14646
Oil Age	hrs	Client Info		5000	982	2000
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	<1
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	<1	0
Aluminum	ppm	ASTM D5185m		0	0	<1
Lead	ppm	ASTM D5185m	>10	0	<1	<1
		ASTM D5185m	>50	3	2	7
Copper Tin	ppm	ASTM D5185m	>50	ა <1	0	0
	ppm		×10	<1	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	1	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		1	<1	0
Magnesium	ppm	ASTM D5185m	100	41	56	23
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	3	2
Zinc	ppm	ASTM D5185m	0	10	2	28
Sulfur	ppm	ASTM D5185m	23500	22403	16182	19610
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	1
Sodium	ppm	ASTM D5185m		11	12	11
Potassium	ppm	ASTM D5185m	>20	1	3	8
Water	%	ASTM D6304	>0.05	0.020	0.024	0.013
ppm Water	ppm	ASTM D6304		204.4	243.7	130
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		11147	1901	9921
Particles >6µm		ASTM D7647	>1300	▲ 5006	542	▲ 5313
Particles >14µm		ASTM D7647		▲ 872	57	▲ 1237
Particles >21µm		ASTM D7647		▲ 186	20	▲ 463
Particles >38µm		ASTM D7647	>4	▲ 7	1	▲ 28
Particles >71µm		ASTM D7647 ASTM D7647		0	0	4
Oil Cleanliness		ISO 4406 (c)	>/17/13	0 21/20/17	16/13	▲ 4 ▲ 20/17
		( )				
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.32	0.357	0.308
1-09-20) Rev: 1			C 0	ntact/Location.		ID - SOUBIRK

Report Id: SOUBIRKC [WUSCAR] 05681190 (Generated: 09/15/2023 08:09:20) Rev: 1

Contact/Location: P. UNDERWOOD - SOUBIRKC



# **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	46.1	45.7	45.23
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						

