




# FUEL REPORT

Sample Rating Trend

ADDITIVES



Area  
**[PMO2H1674160]**  
 Machine Id  
**B160925929**  
 Component  
**Diesel Fuel**  
 Fluid  
**NOT GIVEN (--- GAL)**



## DIAGNOSIS

### Recommendation

We recommend that you drain the fuel from the component if this has not already been done.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is a high amount of particulates present in the fuel. The water content is negligible.

### Fuel Condition

The fuel viscosity is higher than normal. Additive levels indicate the addition of oil. The fuel is no longer serviceable. Sulfur value derived by ASTM D5453 method for ULSD validation.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>DC0019316</b>	---	---
Sample Date	Client Info	<b>20 Oct 2022</b>	---	---
Machine Age	hrs Client Info	<b>270</b>	---	---
Sample Status		<b>SEVERE</b>	---	---

## PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
ASTM Color	scalar *ASTM D1500	<b>L5.5</b>	---	---
Visc @ 40°C	cSt ASTM D445	<b>▲ 3.92</b>	---	---

## SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm ASTM D5185m	<b>337</b>	---	---
Sulfur (UVF)	ppm ASTM D5453	<b>395</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm ASTM D5185m	<1.0	<b>&lt;1</b>	---	---
Sodium	ppm ASTM D5185m	<0.1	<b>0</b>	---	---
Potassium	ppm ASTM D5185m	<0.1	<b>0</b>	---	---
Water	% ASTM D6304	<0.05	<b>0.017</b>	---	---
ppm Water	ppm ASTM D6304	<500	<b>172.6</b>	---	---
% Gasoline	% *In-House	<0.50	<b>0.0</b>	---	---
% Biodiesel	% *In-House	<20.0	<b>0.0</b>	---	---

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	<b>▲ 7527</b>	---	---
Particles >6µm	ASTM D7647	>640	<b>▲ 1673</b>	---	---
Particles >14µm	ASTM D7647	>80	<b>▲ 169</b>	---	---
Particles >21µm	ASTM D7647	>20	<b>▲ 45</b>	---	---
Particles >38µm	ASTM D7647	>4	<b>1</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>▲ 20/18/15</b>	---	---

## HEAVY METALS

method	limit/base	current	history1	history2	
Aluminum	ppm ASTM D5185m	<0.1	<b>0</b>	---	---
Nickel	ppm ASTM D5185m	<0.1	<b>0</b>	---	---
Lead	ppm ASTM D5185m	<0.1	<b>3</b>	---	---
Vanadium	ppm ASTM D5185m	<0.1	<b>0</b>	---	---
Iron	ppm ASTM D5185m	<0.1	<b>&lt;1</b>	---	---
Calcium	ppm ASTM D5185m	<0.1	<b>257</b>	---	---
Magnesium	ppm ASTM D5185m	<0.1	<b>59</b>	---	---
Phosphorus	ppm ASTM D5185m	<0.1	<b>169</b>	---	---
Zinc	ppm ASTM D5185m	<0.1	<b>168</b>	---	---


## SAMPLE IMAGES

method	limit/base	current	history1	history2
Color			no image	no image
Bottom			no image	no image




# FUEL REPORT

## Additives




## GRAPHS

### Pensky-Martens Flash Point (°C)



## Particle Count




## Particle Trend



## Viscosity @ 40°C



## Water (KF)



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : DC0019316 **Received** : 04 Nov 2022  
**Lab Number** : 05685889 **Diagnosed** : 17 Nov 2022  
**Unique Number** : 10205461 **Diagnostician** : Doug Bogart  
**Test Package** : DF-5 ( Additional Tests: API, Screen )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**NATIONAL POWER CORP**  
 4541 PRESLYN DR  
 RALEIGH, NC  
 US 27616  
 Contact: BRANDON RICE  
 brandon.rice@natpow.com  
 T:  
 F: (919)790-9714