

PROBLEM SUMMARY


Built for a lifetime."


Machine Ic KAESER SX 7.5 5703907 (S/N 1050) Component


Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY







RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

THOBELINATION	LOTITE	.00210				
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
Water	%	ASTM D6304	>0.05	A 0.126	▲ 0.056	0.010
ppm Water	ppm	ASTM D6304	>500	<u> </u>	▲ 566.8	100.5
Particles >6µm		ASTM D7647	>1300	<u> </u>		▲ 1724
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		<u> </u>

Customer Id: ANCNORRI Sample No.: KCP49248 Lab Number: 05695754 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED	DMMENDED ACTIONS					
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

HISTORICAL DIAGNOSIS



17 Aug 2021 Diag: Jonathan Hester

We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



13 Jul 2020 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

SAMPLE INCORATIO

Machine Id KAESER SX 7.5 5703907 (S/N 1050) Component

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

Wear


All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.



SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP49248	KCP05336232	KCP10943
Sample Date		Client Info		24 Oct 2022	17 Aug 2021	13 Jul 2020
Machine Age	hrs	Client Info		13105	9048	1789
Oil Age	hrs	Client Info		4057	5784	1475
Oil Changed		Client Info		Changed	Not Changd	Changed
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m		0	0	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m		18	18	28
Tin	ppm	ASTM D5185m		0	<1	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	13	1
Barium	ppm	ASTM D5185m	90	0	0	<1
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	2	10	7
Calcium	ppm		0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	<1	3	6
Zinc	ppm	ASTM D5185m	0	48	50	59
Sulfur	ppm	ASTM D5185m	23500	20621	15225	17376
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	4
Sodium	ppm	ASTM D5185m		2	6	5
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304		0.126	▲ 0.056	0.010
ppm Water	ppm	ASTM D6304		1260	▲ 566.8	100.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		30547		4548
Particles >6µm		ASTM D7647	>1300	<u> </u>		1 724
Particles >14µm		ASTM D7647	>80	61		13
Particles >21µm		ASTM D7647	>20	7		2
Particles >38µm		ASTM D7647	>4	1		0
Particles >71µm		ASTM D7647	>3	0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 22/19/13		1 8/11
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.30	0.264	0.215
(20:30) Boy: 1					oct/Location: A/P	

Report Id: ANCNORRI [WUSCAR] 05695754 (Generated: 10/31/2023 10:20:30) Rev: 1

.264 Contact/Location: A/P ? - ANCNORRI



OIL ANALYSIS REPORT





