



PROBLEM SUMMARY


Sample Rating Trend

WEAR




Machine Id
LOOP - COLD SIDE

Component
Cooling Water
Fluid
NOT GIVEN (--- GAL)




COMPONENT CONDITION SUMMARY


Ferrous Alloys



Glycol Contamination



Particle Trend




RECOMMENDATION

Recommend drain cooling water if not already done and flush with cleaner before refilling with cooling water. We advise that you add cooling water treatment chemicals to combat corrosion per manufacturer's recommendations.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | SEVERE | --- | --- |
|-----------------|------------|--------------|-----------|----------|-----|-----|
| Iron | ppm | ASTM D5185m | | 121 | --- | --- |
| Chlorine | ppm | ASTM D5185m | | 262 | --- | --- |
| Particles >4µm | | ASTM D7647 | >5000 | 13632 | --- | --- |
| Particles >6µm | | ASTM D7647 | >1300 | 7426 | --- | --- |
| Particles >14µm | | ASTM D7647 | >160 | 1264 | --- | --- |
| Particles >21µm | | ASTM D7647 | >40 | 426 | --- | --- |
| Particles >38µm | | ASTM D7647 | >10 | 66 | --- | --- |
| Particles >71µm | | ASTM D7647 | >3 | 7 | --- | --- |
| Oil Cleanliness | | ISO 4406 (c) | >19/17/14 | 21/20/17 | --- | --- |
| Sodium | ppm | ASTM D5185m | | 113 | --- | --- |
| Hardness | mg/L CaCO3 | *In-house | <75 | 165 | --- | --- |

PrtFilter



Customer Id: THRFAI
Sample No.: USP242073
Lab Number: 05697200
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Aaron Black +1
aaron.black@wearcheck.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|----------------------|--------|------|---------|--|
| Change Fluid | --- | --- | ? | Recommend drain cooling water if not already done and flush with cleaner before refilling with cooling water. |
| Flush System | --- | --- | ? | Recommend drain cooling water if not already done and flush with cleaner before refilling with cooling water. |
| Service/change Fluid | --- | --- | ? | We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer's recommendations. |


HISTORICAL DIAGNOSIS



COOLANT REPORT

Sample Rating Trend

WEAR



Machine Id
LOOP - COLD SIDE

Component
Cooling Water
Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

Recommend drain cooling water if not already done and flush with cleaner before refilling with cooling water. We advise that you add cooling water treatment chemicals to combat corrosion per manufacturer's recommendations.

Wear

The iron level is high indicating rust in the system which clogs the cooling system.


Contamination

There is a high amount of particulates present in the cooling water. High concentration of visible sediment present as ferrous oxides (rust) in the cooling water. The high sodium (Na) and chlorine (Cl) levels indicate the possible presence of salt water. Chlorine measured at 262 ppm. Water hardness level is very high at 165 ppm.

Fluid Condition

The pH level of this fluid is within the acceptable limits at 7.5.

Particle Filter (Magn: 500 x)



| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|----------|----------|
| Sample Number | Client Info | | | USP242073 | --- | --- |
| Sample Date | Client Info | | | 09 Nov 2022 | --- | --- |
| Machine Age | hrs | Client Info | | 0 | --- | --- |
| Oil Age | hrs | Client Info | | 0 | --- | --- |
| Oil Changed | Client Info | | | N/A | --- | --- |
| Sample Status | | | | SEVERE | --- | --- |

| PHYSICAL TEST RESULTS | | method | limit/base | current | history1 | history2 |
|------------------------|------------|-------------|------------|--------------|----------|----------|
| Specific Gravity | | *ASTM D1298 | | 1.000 | --- | --- |
| pH | Scale 0-14 | ASTM D1287 | | 7.46 | --- | --- |
| Nitrites | ppm | AP-053:2009 | | 0 | --- | --- |
| Reserve Alkalinity | Scale 0-20 | *ASTM D1121 | | --- | --- | --- |
| Percentage Glycol | % | ASTM D3321 | | 0.0 | --- | --- |
| Freezing Point | °F | ASTM D3321 | | --- | --- | --- |
| Total Dissolved Solids | | | | 17.0 | --- | --- |
| Carboxylate | | | | n/a | --- | --- |

| CORROSION INHIBITORS | | method | limit/base | current | history1 | history2 |
|----------------------|-----|-------------|------------|----------|----------|----------|
| Silicon | ppm | ASTM D5185m | | 0 | --- | --- |
| Phosphorus | ppm | ASTM D5185m | | 0 | --- | --- |
| Boron | ppm | ASTM D5185m | | 0 | --- | --- |
| Molybdenum | ppm | ASTM D5185m | | 3 | --- | --- |


| CORROSION | | method | limit/base | current | history1 | history2 |
|-----------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | | 121 | --- | --- |
| Aluminum | ppm | ASTM D5185m | | <1 | --- | --- |
| Copper | ppm | ASTM D5185m | | 2 | --- | --- |
| Lead | ppm | ASTM D5185m | | <1 | --- | --- |
| Tin | ppm | ASTM D5185m | | 0 | --- | --- |
| Zinc | ppm | ASTM D5185m | | 3 | --- | --- |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|-----------------|-----|--------------|------------|-----------------|----------|----------|
| Chlorine | ppm | ASTM D5185m | | 262 | --- | --- |
| Particles >4µm | | ASTM D7647 | >5000 | 13632 | --- | --- |
| Particles >6µm | | ASTM D7647 | >1300 | 7426 | --- | --- |
| Particles >14µm | | ASTM D7647 | >160 | 1264 | --- | --- |
| Particles >21µm | | ASTM D7647 | >40 | 426 | --- | --- |
| Particles >38µm | | ASTM D7647 | >10 | 66 | --- | --- |
| Particles >71µm | | ASTM D7647 | >3 | 7 | --- | --- |
| Oil Cleanliness | | ISO 4406 (c) | >19/17/14 | 21/20/17 | --- | --- |


| CARRIER SALTS | | method | limit/base | current | history1 | history2 |
|---------------|-----|-------------|------------|------------|----------|----------|
| Sodium | ppm | ASTM D5185m | | 113 | --- | --- |
| Potassium | ppm | ASTM D5185m | | 0 | --- | --- |

| SCALE POTENTIAL | | method | limit/base | current | history1 | history2 |
|-----------------|------------|-------------|------------|------------|----------|----------|
| Calcium | ppm | ASTM D5185m | >100 | 40 | --- | --- |
| Magnesium | ppm | ASTM D5185m | >40 | 16 | --- | --- |
| Hardness | mg/L CaCO3 | *In-house | <75 | 165 | --- | --- |


Glycol Contamination




Particle Count




Particle Trend



Nitrites




Nitrites




| VISUAL | method | limit/base | current | history1 | history2 |
|--------------------|---------|------------|---------------|----------|----------|
| Coolant Color | *Visual | | Black | --- | --- |
| Coolant Appearance | *Visual | Clear | normal | --- | --- |
| Color | | | | no image | no image |
| Bottom | | | | no image | no image |
| PrtFilter | | | | no image | no image |

GRAPHS

Ferrous Alloys




Non-ferrous Metals



Viscosity @ 40°C



Particle Filter (Magn: 500 x)



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP242073 **Received** : 17 Nov 2022
Lab Number : 05697200 **Diagnosed** : 23 Nov 2022
Unique Number : 10221773 **Diagnostician** : Aaron Black

3M - FAIRMONT
 710 NORTH STATE STREET
 FAIRMONT, MN
 US 56031
 Contact: JEFF NELSON
 jnelson2@mmm.com
 T: (507)235-2111
 F: (507)235-2180

To discuss this sample report, contact Customer Service at 1-800-237-1369.

** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)