


PROBLEM SUMMARY

FERMENTATION Machine Id AAA Great Wall NEJ20BB01 - DOSING TANK AGITATOR Component

Gearbox

FUCHS CASSIDA GL 320 (22 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status			ATTENTION	ATTENTION	ABNORMAL	
Particles >4µm	ASTM D7647	>20000	<u> </u>	18268	🔺 151148	
Oil Cleanliness	ISO 4406 (c)	>21/19/16	A 22/18/13	21/18/14	<u> </u>	


Customer Id: NOVBLA Sample No.: WC0714671 Lab Number: 05697504 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		

HISTORICAL DIAGNOSIS



01 Jun 2022 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.



view report

13 Dec 2021 Diag: Wes Davis




We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4 μ m are abnormally high. Particles >6 μ m are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

ISO

10 Aug 2021 Diag: Wes Davis

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles $>4\mu$ m are abnormally high. Particles $>6\mu$ m are notably high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

FERMENTATION AAA Great Wall NEJ20BB01 - DOSING TANK AGITATOR Component

Gearbox

Fluid FUCHS CASSIDA GL 320 (22 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0714671	WC0654058	WC0616378
Sample Date		Client Info		04 Nov 2022	01 Jun 2022	13 Dec 2021
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	4	2	11
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	<1
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	<1	<1
Aluminum	ppm	ASTM D5185m	>25	<1	<1	7
Lead	ppm	ASTM D5185m	>100	<1	0	<1
Copper	ppm	ASTM D5185m	>200	0	0	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Antimony	ppm	ASTM D5185m	>5			0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		0	0	1
Calcium	ppm	ASTM D5185m		3	4	35
Phosphorus	ppm	ASTM D5185m		540	506	421
Zinc	ppm	ASTM D5185m		<1	<1	22
Sulfur	ppm	ASTM D5185m		1147	899	5637
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1	1	5
Sodium	ppm	ASTM D5185m		0	0	2
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.2	0.008	0.004	0.001
ppm Water	ppm	ASTM D6304	>2000	80.3	40.5	11.5
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	A 23061	18268	▲ 151148
Particles >6µm		ASTM D7647	>5000	2138	2281	▲ 39412
Particles >14µm		ASTM D7647	>640	49	87	132
Particles >21µm		ASTM D7647	>160	5	22	14
Particles >38µm		ASTM D7647	>40	1	2	0
Particles >71µm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	A 22/18/13	21/18/14	▲ 24/22/14
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.48	0.52	0.361
·44·22) Boy: 1					Submitted By:	


Report Id: NOVBLA [WUSCAR] 05697504 (Generated: 11/27/2023 17:44:32) Rev: 1


Submitted By: ALAN NELSON



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	304	3 07	209
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color						





* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Page 4 of 4

F: