




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
GUAY SON [CONHER]
 Machine Id
MAIN ENGINE
 Component
Auxiliary Engine
 Fluid
Xtra Rev 15W40 (8 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KL0011231	KL0010142	KL0009212
Sample Date	Client Info			12 Nov 2022	05 Oct 2022	23 Mar 2022
Machine Age	hrs	Client Info		11558	10542	0
Oil Age	hrs	Client Info		1016	430	0
Oil Changed	Client Info			Not Changed	Not Changed	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>4.0		<1.0	<1.0	<1.0
Water	WC Method	>0.1		NEG	NEG	NEG
Glycol	WC Method			NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	40	31	5
Chromium	ppm	ASTM D5185m	>20	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m	>2	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>20	2	2	2
Lead	ppm	ASTM D5185m	>40	4	3	0
Copper	ppm	ASTM D5185m	>330	4	3	<1
Tin	ppm	ASTM D5185m	>15	<1	<1	<1
Antimony	ppm	ASTM D5185m		---	---	---
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0





ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		6	46	303
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		12	61	105
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		54	257	525
Calcium	ppm	ASTM D5185m		2847	1989	1388
Phosphorus	ppm	ASTM D5185m		1060	918	815
Zinc	ppm	ASTM D5185m		1315	1113	964
Sulfur	ppm	ASTM D5185m		4121	3647	2569

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	7	6	6
Sodium	ppm	ASTM D5185m		2	<1	2
Potassium	ppm	ASTM D5185m	>20	3	2	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.9	0.3	0.1
Nitration	Abs/cm	*ASTM D7624	>20	10.8	9.8	7.7
Sulfation	Abs./1mm	*ASTM D7415	>30	20.8	20.9	22.5



OIL ANALYSIS REPORT








FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		2101	4304	26319
Particles >6µm	ASTM D7647	>5000	1145	2345	▲ 14337
Particles >14µm	ASTM D7647	>640	195	399	▲ 2440
Particles >21µm	ASTM D7647	>160	66	134	▲ 822
Particles >38µm	ASTM D7647	>40	10	21	▲ 127
Particles >71µm	ASTM D7647	>10	1	2	▲ 13
Oil Cleanliness	ISO 4406 (c)	>19/16	17/15	18/16	▲ 21/18

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414	>25	14.5	16.5	17.9
Base Number (BN)	mg KOH/g ASTM D2896		9.17	7.58	8.25

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual	>0.1	NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt ASTM D445		13.2	12.6	13.5

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0011231 **Received** : 25 Nov 2022
Lab Number : **05703097** **Diagnosed** : 29 Nov 2022
Unique Number : 10232671 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CONOR
 JUAREZ 348
 HERMOSILLO,
 MX 83140
 Contact: EDUARDO GARCIA
 egarcia.comsa@gmail.com
 T: (526)622-1581 x:81
 F: x: