


# PROBLEM SUMMARY

Sample Rating Trend



**DIRT**




Machine Id  
**MYCOM A**

Component  
**Compressor**


Fluid  
**TULCO LUBSOIL LPG WI 100 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Silicon (ppm)



## RECOMMENDATION

Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Silicon	ppm	ASTM D5185m >25	▲ <b>35</b>	▲ 37	▲ 111
Particles >4µm		ASTM D7647 >10000	▲ <b>100713</b>	9886	▲ 63348
Particles >6µm		ASTM D7647 >1300	▲ <b>34517</b>	▲ 1661	▲ 16426
Particles >14µm		ASTM D7647 >320	▲ <b>4038</b>	34	▲ 994
Particles >21µm		ASTM D7647 >80	▲ <b>1370</b>	9	▲ 229
Particles >38µm		ASTM D7647 >20	▲ <b>76</b>	0	4
Oil Cleanliness		ISO 4406 (c) >20/17/15	▲ <b>24/22/19</b>	▲ 20/18/12	▲ 23/21/17

Customer Id: MELMELTX  
Sample No.: TO50000123  
Lab Number: 05708432  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 09 Jun 2022 Diag: Don Baldrige

DIRT



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 31 Jan 2022 Diag: Doug Bogart

DIRT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid.

view report



### 06 May 2021 Diag: Jonathan Hester

WATER




The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. There is a moderate concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**MYCOM A**  
Component  
**Compressor**  
Fluid  
**TULCO LUBSOIL LPG WI 100 (--- GAL)**

**DIAGNOSIS**

**Recommendation**  
Resample at the next service interval to monitor.

**Wear**  
All component wear rates are normal.

**Contamination**  
There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

**Fluid Condition**  
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO50000123</b>	TO50000121	TO50000086
Sample Date	Client Info		<b>01 Dec 2022</b>	09 Jun 2022	31 Jan 2022
Machine Age	mths	Client Info	<b>0</b>	0	0
Oil Age	mths	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>Filtered</b>	Filtered	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>&lt;1</b>	0	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	<b>0</b>	<1	2
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m >25	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m >50	<b>0</b>	0	<1
Tin	ppm	ASTM D5185m >15	<b>&lt;1</b>	1	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	<1	3
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m 0	<b>2</b>	<1	<1
Calcium	ppm	ASTM D5185m	<b>0</b>	0	<1
Phosphorus	ppm	ASTM D5185m 0	<b>38</b>	17	14
Zinc	ppm	ASTM D5185m 0	<b>5</b>	0	0
Sulfur	ppm	ASTM D5185m 0	<b>1607</b>	2656	2309


CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>▲ 35</b>	▲ 37	▲ 111
Sodium	ppm	ASTM D5185m	<b>1</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	2
Water	%	ASTM D6304 >2.26	<b>0.172</b>	0.963	0.357
ppm Water	ppm	ASTM D6304 >22600	<b>1725.0</b>	9630	3578.2

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>▲ 100713</b>	9886	▲ 63348
Particles >6µm	ASTM D7647	>1300	<b>▲ 34517</b>	▲ 1661	▲ 16426
Particles >14µm	ASTM D7647	>320	<b>▲ 4038</b>	34	▲ 994
Particles >21µm	ASTM D7647	>80	<b>▲ 1370</b>	9	▲ 229
Particles >38µm	ASTM D7647	>20	<b>▲ 76</b>	0	4
Particles >71µm	ASTM D7647	>4	<b>4</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/17/15	<b>▲ 24/22/19</b>	▲ 20/18/12	▲ 23/21/17


FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.79</b>	0.401	0.705

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Silicon (ppm)




### Water



### Viscosity @ 100°C



### Water




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	VLITE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	113	110	110
Visc @ 100°C	cSt	ASTM D445	19	18.6	19.28
Viscosity Index (VI)	Scale	ASTM D2270	189	190	197

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color

Bottom




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO50000123 **Received** : 05 Dec 2022  
**Lab Number** : 05708432 **Diagnosed** : 06 Dec 2022  
**Unique Number** : 10243007 **Diagnostician** : Angela Borella  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**MELISSA RENEWABLES**  
 3820 SAM RAYBURN HWY  
 MELISSA, TX  
 US 75454  
 Contact: BILL PALMER  
 bpalmer@morrowenergy.com  
 T: (972)529-8442  
 F: