


PROBLEM SUMMARY

Sample Rating Trend




Machine Id
VILTER C

Component
Compressor


Fluid
TULCO LUBSOIL LPG WI 100 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Silicon (ppm)



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Silicon	ppm	ASTM D5185m >25	▲ 81	▲ 83	▲ 124
Particles >4µm		ASTM D7647 >10000	▲ 46325	▲ 137229	▲ 262692
Particles >6µm		ASTM D7647 >1300	▲ 5190	▲ 26799	▲ 170047
Oil Cleanliness		ISO 4406 (c) >20/17/15	▲ 23/20/14	▲ 24/22/15	▲ 25/25/20

Customer Id: MELMELTX
Sample No.: TO50000124
Lab Number: 05708436
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

09 Jun 2022 Diag: Jonathan Hester

DIRT



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



31 Jan 2022 Diag: Doug Bogart

DIRT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid.

view report



06 May 2021 Diag: Jonathan Hester

DIRT




We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
VILTER C

Component
Compressor

Fluid
TULCO LUBSOIL LPG WI 100 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO50000124	TO50000127	TO50000082
Sample Date	Client Info	01 Dec 2022	09 Jun 2022	31 Jan 2022
Machine Age	mths Client Info	0	0	0
Oil Age	mths Client Info	0	0	0
Oil Changed	Client Info	Filtered	Changed	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	1	1	1
Chromium ppm	ASTM D5185m >10	0	0	0
Nickel ppm	ASTM D5185m	0	0	0
Titanium ppm	ASTM D5185m	0	0	0
Silver ppm	ASTM D5185m	0	0	0
Aluminum ppm	ASTM D5185m >25	<1	<1	<1
Lead ppm	ASTM D5185m >25	0	0	0
Copper ppm	ASTM D5185m >50	0	0	0
Tin ppm	ASTM D5185m >15	<1	<1	1
Antimony ppm	ASTM D5185m	---	---	<1
Vanadium ppm	ASTM D5185m	0	0	0
Cadmium ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m 0	0	0	0
Barium ppm	ASTM D5185m	0	0	0
Molybdenum ppm	ASTM D5185m 0	0	0	0
Manganese ppm	ASTM D5185m	0	0	0
Magnesium ppm	ASTM D5185m 0	1	<1	0
Calcium ppm	ASTM D5185m	0	0	0
Phosphorus ppm	ASTM D5185m 0	33	5	8
Zinc ppm	ASTM D5185m 0	4	0	0
Sulfur ppm	ASTM D5185m 0	6017	4448	4886

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	▲ 81	▲ 83	▲ 124
Sodium ppm	ASTM D5185m	0	<1	0
Potassium ppm	ASTM D5185m >20	0	0	0
Water %	ASTM D6304 >2.26	0.007	0.012	0.222
ppm Water	ASTM D6304 >22600	74.9	122.7	2223.6

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 46325	▲ 137229	▲ 262692
Particles >6µm	ASTM D7647 >1300	▲ 5190	▲ 26799	▲ 170047
Particles >14µm	ASTM D7647 >320	100	304	▲ 5045
Particles >21µm	ASTM D7647 >80	21	37	▲ 276
Particles >38µm	ASTM D7647 >20	1	0	4
Particles >71µm	ASTM D7647 >4	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/17/15	▲ 23/20/14	▲ 24/22/15	▲ 25/25/20

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045	0.87	0.115	0.157

OIL ANALYSIS REPORT


▲ Particle Trend




▲ Silicon (ppm)




Water



Viscosity @ 100°C



Water




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	113	125	121
Visc @ 100°C	cSt	ASTM D445	19	19.2	18.3
Viscosity Index (VI)	Scale	ASTM D2270	189	174	169

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color

Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50000124 **Received** : 05 Dec 2022
Lab Number : 05708436 **Diagnosed** : 06 Dec 2022
Unique Number : 10243011 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MELISSA RENEWABLES
 3820 SAM RAYBURN HWY
 MELISSA, TX
 US 75454
 Contact: BILL PALMER
 bpalmer@morrowenergy.com
 T: (972)529-8442
 F: