




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**GUAY SON [22188]**  
 Machine Id  
**Base Line IBACO XTRA REV 15W-40**  
 Component  
**New (Unused) Oil**  
 Fluid  
**Xtra Rev 15W-40 (--- GAL)**

## DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample. ( Customer Sample Comment: Batch #22188 )

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KL0011289</b>	KL0010114	KL0010172
Sample Date	Client Info			<b>02 Dec 2022</b>	28 Jul 2022	17 May 2022
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		<b>1</b>	2	2
Chromium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185m		<b>5</b>	<1	<1
Aluminum	ppm	ASTM D5185m		<b>3</b>	<1	2
Lead	ppm	ASTM D5185m		<b>1</b>	1	<1
Copper	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Tin	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>3</b>	2	461
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	3	118
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>11</b>	15	540
Calcium	ppm	ASTM D5185m		<b>2826</b>	2503	1544
Phosphorus	ppm	ASTM D5185m		<b>1178</b>	1018	859
Zinc	ppm	ASTM D5185m		<b>1412</b>	1231	1001
Sulfur	ppm	ASTM D5185m		<b>3938</b>	2926	3169






CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		<b>6</b>	6	9
Sodium	ppm	ASTM D5185m		<b>0</b>	2	<1
Potassium	ppm	ASTM D5185m	>20	<b>6</b>	7	<1

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>---</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624		<b>---</b>	4.8	4.8
Sulfation	Abs/.1mm	*ASTM D7415		<b>---</b>	13.4	20.3

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>4043</b>	546	---
Particles >6µm		ASTM D7647	>1300	<b>865</b>	297	---
Particles >14µm		ASTM D7647	>160	<b>6</b>	51	---
Particles >21µm		ASTM D7647	>40	<b>1</b>	17	---
Particles >38µm		ASTM D7647	>10	<b>0</b>	3	---
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>17/14	<b>17/10</b>	15/13	---



# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs.:1mm	*ASTM D7414		---	5.7	14.5
Base Number (BN)	mg KOH/g	ASTM D2896		<b>10.28</b>	10.2	8.8

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual		<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		<b>117.5</b>	116	105
Visc @ 100°C	cSt	ASTM D445		<b>15.01</b>	14.9	14.54
Viscosity Index (VI)	Scale	ASTM D2270		<b>132</b>	132	142

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	
Bottom					no image	



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KL0011289 **Received** : 08 Dec 2022  
**Lab Number** : **05712883** **Diagnosed** : 12 Dec 2022  
**Unique Number** : 10247458 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: FT-IR, ICP-NewOil, KV100, PrtCount, TBN,

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**CONOR**  
 JUAREZ 348  
 HERMOSILLO,  
 MX 83140  
 Contact: EDUARDO GARCIA  
 egarcia.comsa@gmail.com

T: (526)622-1581 x:81

F: x: