




# FUEL REPORT

## Sample Rating Trend



WATER



Machine Id  
**COLUMBUS REGIONAL HOSPITAL TANK 2 8K AST**

Component  
**Diesel Fuel**  
Fluid

**No.2 DIESEL FUEL (LOW-SULPHUR) (--- GAL)**

### DIAGNOSIS

#### Recommendation

We advise that you follow the water drain-off procedure for this component. We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

#### Contaminants

Excessive free water present. Moderate concentration of visible dirt/debris present in the fuel. There is a moderate amount of visible silt present in the sample. There is a light concentration of Bacteria, Yeast and/or Fungus present in the sample.

#### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC05713372</b>	WC05426182	WC04798381
Sample Date	Client Info		<b>08 Dec 2022</b>	16 Dec 2021	12 Sep 2019
Machine Age	hrs	Client Info	<b>0</b>	0	0
Sample Status			<b>SEVERE</b>	ABNORMAL	SEVERE

### PHYSICAL PROPERTIES

	method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	0.839	---	0.840	0.847
Fuel Color	text	*Visual Screen	Yellow	---	Red
ASTM Color	scalar	*ASTM D1500	<b>L4.0</b>	L5.0	L5.5
Visc @ 40°C	cSt	ASTM D445	<b>3.0</b>	2.42	2.74
Pensky-Martens Flash Point	°C	*PMCC Calculated	<b>52</b>	65	60

### SULFUR CONTENT

	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	250	<b>0</b>	20
Sulfur (UVF)	ppm	ASTM D5453		<b>6</b>	22

### DISTILLATION

	method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	---	172
5% Distillation Point	°C	ASTM D86		---	193
10% Distill Point	°C	ASTM D86	201	---	202
15% Distillation Point	°C	ASTM D86		---	208
20% Distill Point	°C	ASTM D86	216	---	216
30% Distill Point	°C	ASTM D86	230	---	230
40% Distill Point	°C	ASTM D86	243	---	244
50% Distill Point	°C	ASTM D86	255	---	257
60% Distill Point	°C	ASTM D86	267	---	272
70% Distill Point	°C	ASTM D86	280	---	287
80% Distill Point	°C	ASTM D86	295	---	304
85% Distillation Point	°C	ASTM D86		---	314
90% Distill Point	°C	ASTM D86	310	---	325
95% Distillation Point	°C	ASTM D86		---	341
Final Boiling Point	°C	ASTM D86	341	---	350
Distillation Residue	%	ASTM D86	3.0	---	1.4
Distillation Loss	%	ASTM D86	3.0	---	0.7

### IGNITION QUALITY



	method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.7	---	37.0	35.6
Cetane Index	ASTM D4737	<40.0	---	48.1	47.2

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>&lt;1</b>	0
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	<1
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	0
Water	%	ASTM D6304	<0.05	<b>0.013</b>	0.003
ppm Water	ppm	ASTM D6304	<500	<b>138.6</b>	26.9
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	0.0
% Biodiesel	%	*In-House	<20.0	<b>1.8</b>	0.0







# FUEL REPORT



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	---	▲ 48406	---
Particles >6µm	ASTM D7647	>640	---	▲ 12359	---
Particles >14µm	ASTM D7647	>80	---	▲ 825	---
Particles >21µm	ASTM D7647	>20	---	▲ 142	---
Particles >38µm	ASTM D7647	>4	---	▲ 9	---
Particles >71µm	ASTM D7647	>3	---	0	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	---	▲ 23/21/17	---

MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml WC-Method	>=100000	0	---	0
Yeast	CFU/ml WC-Method	>=100000	▲ 10	---	0
Mold	Colonies WC-Method	MODER	---	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185m	<0.1	0	<1	0
Nickel	ppm ASTM D5185m	<0.1	0	1	0
Lead	ppm ASTM D5185m	<0.1	0	0	1
Vanadium	ppm ASTM D5185m	<0.1	0	0	0
Iron	ppm ASTM D5185m	<0.1	<1	0	0
Calcium	ppm ASTM D5185m	<0.1	0	0	0
Magnesium	ppm ASTM D5185m	<0.1	0	0	0
Phosphorus	ppm ASTM D5185m	<0.1	2	0	0
Zinc	ppm ASTM D5185m	<0.1	0	0	<1

SAMPLE IMAGES	method	limit/base	current	history1	history2	
Color						no image
Bottom						no image



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC05713372     **Received** : 08 Dec 2022  
**Lab Number** : 05713372     **Diagnosed** : 16 Dec 2022  
**Unique Number** : 10247947     **Diagnostician** : Doug Bogart  
**Test Package** : DF-2 ( Additional Tests: Bacteria, Screen )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**GAINES OIL COMPANY**  
 2346 S MAIN ST  
 GOLDSTON, NC  
 US 27252  
 Contact: CHIP POOLE  
 chip@gainesoil.com  
 T: (919)898-2231  
 F: (919)898-2981