




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
7145104 (S/N 1050)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KCP49856 | KCP45308 | KCP37977 |
| Sample Date | Client Info | | | 02 Dec 2022 | 31 Mar 2022 | 03 Sep 2021 |
| Machine Age | hrs | Client Info | | 9558 | 7687 | 5990 |
| Oil Age | hrs | Client Info | | 1871 | 1700 | 3837 |
| Oil Changed | Client Info | | | Not Chngd | Not Chngd | Changed |
| Sample Status | | | | NORMAL | ABNORMAL | NORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|---------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | <1 | <1 | <1 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 2 | 1 | 3 |
| Lead | ppm | ASTM D5185m | >10 | <1 | <1 | 0 |
| Copper | ppm | ASTM D5185m | >50 | 7 | 4 | 7 |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |






| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|---------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | <1 | 0 |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 100 | 25 | 51 | 12 |
| Calcium | ppm | ASTM D5185m | 0 | 0 | <1 | 0 |
| Phosphorus | ppm | ASTM D5185m | 0 | 8 | 10 | <1 |
| Zinc | ppm | ASTM D5185m | 0 | 147 | 51 | 89 |
| Sulfur | ppm | ASTM D5185m | 23500 | 23325 | 18101 | 18456 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|---------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | 1 | 3 | 2 |
| Sodium | ppm | ASTM D5185m | | 18 | 17 | 17 |
| Potassium | ppm | ASTM D5185m | >20 | 6 | 8 | 6 |
| Water | % | ASTM D6304 | >0.05 | 0.019 | 0.032 | 0.020 |
| ppm Water | ppm | ASTM D6304 | >500 | 191.5 | 327.7 | 201.8 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|----------|----------|----------|
| Particles >4µm | | ASTM D7647 | | 4632 | 8349 | 1484 |
| Particles >6µm | | ASTM D7647 | >1300 | 1267 | ▲ 2381 | 403 |
| Particles >14µm | | ASTM D7647 | >80 | 58 | ▲ 374 | 39 |
| Particles >21µm | | ASTM D7647 | >20 | 7 | ▲ 128 | 13 |
| Particles >38µm | | ASTM D7647 | >4 | 1 | ▲ 11 | 1 |
| Particles >71µm | | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | 19/17/13 | ▲ 18/16 | 16/12 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|---------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 1.0 | 0.40 | 0.35 | 0.377 |


OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | VLITE | LIGHT |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 45 | 46.5 | 44.7 | 46.6 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP49856 **Received** : 12 Dec 2022
Lab Number : 05715906 **Diagnosed** : 14 Dec 2022
Unique Number : 10255482 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

GEORGIA HI TECH FABRICATORS
 2001 COMMERCE DR
 VIDALIA, GA
 US 30474
 Contact: MAINTENANCE
 maintenance@gahitech.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)