



# PROBLEM SUMMARY

Sample Rating Trend

INSOLUBLES




Machine Id  
**VACUUM DEGASSER PUMP**  
 Component  
**Hydraulic System**  
 Fluid  
**SHELL TELLUS S2 MX 46 (15000 GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Varnish Potential



## RECOMMENDATION

We recommend that you use depth filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. Additional phone discussion regarding this analysis included information that the spot test for varnish on the MPC indicated that not all of the varnish components are purely varnish. Pure varnish will react to the test chemical and this MPC did not react as typical for varnish, suggesting there is a secondary process happening in the lubricant creating solids such as ash or a chemical conversion to another chemical or polymer that is insoluble. This may be a result of mixing lubricant with incompatible additives, or may be a result of a combustion process such as filtration static arcing or microdieseling. Please note that this is a corrected copy of this report to include additional commentary to document phone conversation points.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>SEVERE</b>	---	---
MPC Varnish Potential	Scale	ASTM D7843	>15	▲ 55	---	---

Customer Id: GENWAR  
 Sample No.: WC0766768  
 Lab Number: 05716377  
 Test Package: AOM 1



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Aaron Black +1  
[aaron.black@wearcheck.com](mailto:aaron.black@wearcheck.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS






Action	Status	Date	Done By	Description
Resample	MISSED	Jan 30 2023	?	We recommend an early resample to monitor this condition.
Filter Fluid	MISSED	Jan 30 2023	?	We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level.

## HISTORICAL DIAGNOSIS





# OIL ANALYSIS REPORT






FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.33</b>	---	---
Anti-Oxidant 1	%	ASTM D6971	<25	<b>69</b>	---	---
Anti-Oxidant 2	%	ASTM D6971	<25	<b>67</b>	---	---
Anti-Oxidant 3	%	ASTM D6971	<25	<b>158</b>	---	---
MPC Varnish Potential	Scale	ASTM D7843	>15	<b>▲ 55</b>	---	---

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	---	---
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	---	---
Silt	scalar	*Visual	NONE	<b>NONE</b>	---	---
Debris	scalar	*Visual	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	---	---
Appearance	scalar	*Visual	NORML	<b>NORML</b>	---	---
Odor	scalar	*Visual	NORML	<b>NORML</b>	---	---
Emulsified Water	scalar	*Visual	>0.05	<b>NEG</b>	---	---
Free Water	scalar	*Visual		<b>NEG</b>	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.0	<b>45.1</b>	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color					no image	no image
Bottom					no image	no image
MPC					no image	no image



Certificate L2367


**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0766768 **Received** : 13 Dec 2022  
**Lab Number** : 05716377 **Tested** : 20 Dec 2022  
**Unique Number** : 10255953 **Diagnosed** : 18 Jan 2023 - Aaron Black  
**Test Package** : AOM 1 ( Additional Tests: KF )

**GENERAL MOTORS VPC BUILDING**  
 30003 VAN DYKE AVE.  
 WARREN, MI  
 US 48090  
 Contact: DANIEL BARKUME  
 daniel.barkume@gm.com  
 T: (586)489-5310  
 F: (586)575-1675


To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)



MPC (Varnish Test)



Sample Color & Clarity



*This page left intentionally blank*