


## **PROBLEM SUMMARY**

KAESER SM 10 7181396 (S/N 1279)

Compressor

KAESER SIGMA (OEM) FG-460 (--- QTS)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

THOBEEMINTIO TECT	11200210				
Sample Status			ABNORMAL	ABNORMAL	
Particles >6µm	ASTM D7647	>1300	<u> </u>	<u> </u>	
Particles >14µm	ASTM D7647	>80	<b>4206</b>	<b>1</b> 88	
Particles >21µm	ASTM D7647	>20	<u> </u>	<b>4</b> 6	
Particles >38µm	ASTM D7647	>4	<b>1</b> 3	0	
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>	🔺 20/19/15	


Customer Id: CORTUR Sample No.: KCP49307 Lab Number: 05721413 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED AC	CTIONS			
Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.

### HISTORICAL DIAGNOSIS

### 18 Apr 2022 Diag: Jonathan Hester ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

# KAESER SM 10 7181396 (S/N 1279)

**Compressor** Fluid

KAESER SIGMA (OEM) FG-460 (--- QTS)

### DIAGNOSIS

#### A Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear


All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP49307	KCP38071	
Sample Date		Client Info		23 Nov 2022	18 Apr 2022	
Machine Age	hrs	Client Info		4953	1722	
Oil Age	hrs	Client Info		0	1722	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	5	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m		3	6	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	1	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	<1	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m	500	122	165	
Zinc	ppm	ASTM D5185m		135	213	
Sulfur	ppm	ASTM D5185m		2330	5934	
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	1	
Water	%	ASTM D6304	>0.05	0.006	0.003	
ppm Water	ppm	ASTM D6304	>500	68.9	33.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		82342	8658	
Particles >6µm		ASTM D7647	>1300	<u> </u>	▲ 2952	
Particles >14µm		ASTM D7647	>80	<u> </u>	<b>1</b> 88	
Particles >21µm		ASTM D7647	>20	<u> </u>	<b>4</b> 6	
Particles >38µm		ASTM D7647	>4	<u> </u>	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>4/23/19</b>	▲ 20/19/15	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	0.52	0.55	

Contact/Location: VICTOR ? - CORTUR



## **OIL ANALYSIS REPORT**



scalar scalar scalar scalar scalar scalar scalar scalar	*Visual *Visual *Visual *Visual *Visual	NONE NONE NONE NONE	NONE NONE NONE	NONE NONE NONE	
scalar scalar scalar scalar scalar	*Visual *Visual *Visual	NONE NONE	NONE		
scalar scalar scalar scalar	*Visual *Visual	NONE	-	NONE	
scalar scalar scalar	*Visual		NONE		
scalar scalar		NONE	NONE	NONE	
scalar	*Visual		LIGHT	NONE	
		NONE	NONE	NONE	
scalar	*Visual	NORML	NORML	NORML	
000.00	*Visual	NORML	NORML	NORML	
scalar	*Visual	>0.05	NEG	NEG	
scalar	*Visual		NEG	NEG	
ES	method	limit/base	current	history1	history2
cSt	ASTM D445	46	47.3	45.5	
	method	limit/base	current	history1	history2
					no image
			S		
				6.351	no image
					0
			De attala de la		
					т26
		100.000			
		122,880			-24
		30,720			-22
		7 680	. /		-20
	*********			/	
		1,920 Nov2	· · · · · ·		-18
		·편 480		• )	-16
		r of pa			
			†	<u>۱</u>	114
			-		-12
		8			10
			elevrevernal O		
		23/22	•••••••		
		Nov. 0		14	200
			Acid Number	14μ Ζ1μ	36µ 71µ
		( <sup>B</sup> H)	Rase		
		및 1.50 문	- 0		
		a 1.00	•		
		N 0.50	-		
		0.00			
		v23/2	or18/2		
		No	Ag		
)1 Madia		rv NC 27519	1	CORT	EZ GROWER
					CORTEZ AV
	cSt	cSt ASTM D445 method	cSt ASTM D445 46 method limit/base 491,520 122,880 30,720 122,880 30,720 122,880 122,880 122,880 122,880 122,880 120, 100, 1	CSt ASTM D445 46 47.3 Method limit/base current Method limit/base current	cSt ASTM D445 46 47.3 45.5 <u>method limit/base current history1</u> <u>method limit/base</u> <u>current of limit/base</u> <u>price Court</u> <u>method limit/base</u> <u>price Court</u> <u>price Co</u>

Diagnostician : Jonathan Hester



Certificate L2367

Laboratory

Sample No.

Lab Number

Unique Number : 10260989

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.