


# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**7352685 (S/N 1114)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) FG-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KC103587</b>	KC73030	KC93011
Sample Date	Client Info		<b>28 Dec 2022</b>	13 Jan 2022	01 Mar 2021
Machine Age	hrs	Client Info	<b>11791</b>	6379	5369
Oil Age	hrs	Client Info	<b>5400</b>	4360	2899
Oil Changed	Client Info		<b>Changed</b>	Changed	Changed
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>3</b>	8	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >10	<b>3</b>	<1	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>17</b>	24	▲ 75
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	2
Barium	ppm	ASTM D5185m	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	4	0
Calcium	ppm	ASTM D5185m	<b>0</b>	2	0
Phosphorus	ppm	ASTM D5185m 500	<b>196</b>	325	199
Zinc	ppm	ASTM D5185m	<b>255</b>	443	235

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>2</b>	<1	0
Sodium	ppm	ASTM D5185m	<b>0</b>	18	<1
Potassium	ppm	ASTM D5185m >20	<b>1</b>	8	0
Water	%	ASTM D6304 >0.05	<b>0.022</b>	▲ 0.764	0.003
ppm Water	ppm	ASTM D6304 >500	<b>223.0</b>	▲ 7640	31.1






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>82710</b>	---	2176
Particles >6µm	ASTM D7647	>1300	▲ <b>29985</b>	---	880
Particles >14µm	ASTM D7647	>80	▲ <b>1249</b>	---	79
Particles >21µm	ASTM D7647	>20	▲ <b>425</b>	---	18
Particles >38µm	ASTM D7647	>4	▲ <b>61</b>	---	0
Particles >71µm	ASTM D7647	>3	<b>2</b>	---	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>24/22/17</b>	---	17/13

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.5	<b>0.55</b>	0.467	0.565

# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	46.5	46.5	45.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC103587  
**Lab Number** : 05732984  
**Unique Number** : 10282582  
**Test Package** : IND 2  
**Received** : 06 Jan 2023  
**Tested** : 10 Jan 2023  
**Diagnosed** : 10 Jan 2023 - Doug Bogart

**PIERRES ICE CREAM**  
 6200 EUCLID AVE  
 CLEVELAND, OH  
 US 44103  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)