


OIL ANALYSIS REPORT

Sample Rating Trend







CL-300

Component Compressor

NOT GIVEN (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

						· •
				Jan 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
	., (11011		minu bacc			
Sample Number		Client Info		TO60000511		
Sample Date	la u a	Client Info		10 Jan 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0 N/A		
Oil Changed		Client inio		NORMAL		
Sample Status				NONWAL		
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		<1		
Phosphorus	ppm	ASTM D5185m		321		
Zinc	ppm	ASTM D5185m		1		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D6304	>0.1	0.004		
ppm Water	ppm	ASTM D6304	>1000	47.8		
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>10000	820		
Particles >6µm		ASTM D7647	>2500	107		
Particles >14µm		ASTM D7647	>320	8		
Particles >21µm		ASTM D7647	>80	1		
Particles >38µm		ASTM D7647	>20	0		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/14/10		
FLUID DEGRADA	TION _	method	limit/base	current	history 1	history 2
Acid Number (AN)	ma 1/011/-	VCTM D004E		0.02		


Acid Number (AN)

mg KOH/g ASTM D8045

0.92



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: 05736099

: TO60000511 : 10285697

Received Diagnosed

: 12 Jan 2023 Diagnostician : Jonathan Hester Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TULSA, OK US 74115 Contact: DYLAN COPE dylancope@tulco.com

T: (800)375-2347 F: x: