




PROBLEM SUMMARY

Sample Rating Trend



WATER



Area
LFC-1030-CM-01-CM023
 Machine Id
P201SH02-1030 - SURGE HOPPER AGITATOR #1 DRIVE
 Component
Transmission
 Fluid
LE 4220 (--- GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the fluid and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>200	▲ 263	51	▲ 301
Water	%	ASTM D6304	>0.1	● 1.09	---	▲ 0.339
ppm Water	ppm	ASTM D6304	>1000	● 10900	---	▲ 3390
Emulsified Water	scalar	*Visual	>0.1	● 0.2%	NEG	0.2%

Customer Id: LEPALL
 Sample No.: WC0767407
 Lab Number: 05738477
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the fluid and perform a filter service on this component if not already done.
Change Filter	---	---	?	We recommend that you drain the fluid and perform a filter service on this component if not already done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

14 Jul 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



16 Jan 2020 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We recommend an early resample to monitor this condition. Gear wear is indicated. Appearance is milky. There is a light concentration of water present in the fluid. The AN level is acceptable for this fluid.

view report



19 Jul 2019 Diag: Jonathan Hester

WEAR



No corrective action is recommended at this time. Resample at the next service interval to monitor. Gear wear is indicated. There is no indication of any contamination in the fluid. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
LFC-1030-CM-01-CM023
 Machine Id
P201SH02-1030 - SURGE HOPPER AGITATOR #1 DRIVE
 Component
Transmission
 Fluid
LE 4220 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend that you drain the fluid and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

Wear

Gear wear is indicated.

Contamination

Appearance is milky. There is a high concentration of water present in the fluid.

Fluid Condition

The AN level is acceptable for this fluid. The fluid is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0767407	WC0587048	WC0402615
Sample Date	Client Info		09 Jan 2023	14 Jul 2021	16 Jan 2020
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	▲ 263	51	▲ 301
Chromium	ppm	ASTM D5185m	>10	3	<1	7
Nickel	ppm	ASTM D5185m		2	<1	4
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>50	1	0	<1
Lead	ppm	ASTM D5185m	>50	<1	<1	<1
Copper	ppm	ASTM D5185m	>200	2	<1	<1
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m		---	<1	0
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	1	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	0
Manganese	ppm	ASTM D5185m		2	<1	1
Magnesium	ppm	ASTM D5185m		0	1	<1
Calcium	ppm	ASTM D5185m		0	0	<1
Phosphorus	ppm	ASTM D5185m		419	407	320
Zinc	ppm	ASTM D5185m		12	9	12
Sulfur	ppm	ASTM D5185m		1580	1041	1752

CONTAMINANTS





	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	8	5	18
Sodium	ppm	ASTM D5185m		7	0	2
Potassium	ppm	ASTM D5185m	>20	2	2	0
Water	%	ASTM D6304	>0.1	● 1.09	---	▲ 0.339
ppm Water	ppm	ASTM D6304	>1000	● 10900	---	▲ 3390

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.67	0.607	1.081



OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ MILKY	▲ MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	● 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	243	227	210

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0767407 **Recieved** : 13 Jan 2023
Lab Number : 05738477 **Diagnosed** : 16 Jan 2023
Unique Number : 10293076 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF)

LEPRINO FOODS - ALLENDALE
 4700 RICH STREET
 ALLENDALE, MI
 US 49401
 Contact: BILL FERRIER
 BFERRIER@LEPRINOFOODS.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: