

PROBLEM SUMMARY


FITODELINI SOMMATI

IRON STAR [200006142] Machine Id 15WEA88308


Component

Wind Turbine Gearbox

GEAR OIL (PAO) ISO 320 (--- LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL					
Particles >6µm	ASTM D7647	>320	1484	△ 698					
Particles >14μm	ASTM D7647	>40	77	18					
Particles >21μm	ASTM D7647	>10	<u> </u>	5					
Oil Cleanliness	ISO 4406 (c)	>/15/12	22/18/13	<u>22/17/11</u>					

Customer Id: NORDEX Sample No.: WC05739624 Lab Number: 05739624 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Sep 27 2023	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

10 Jun 2022 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Confirm oil type. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.






OIL ANALYSIS REPORT

IRON STAR [200006142] 15WEA88308

Wind Turbine Gearbox

GEAR OIL (PAO) ISO 320 (--- LTR)



Sample Rating Trend



DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun 2022	Jan 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC05739624	NX05596453	
Sample Date		Client Info		15 Jan 2023	10 Jun 2022	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>50	8	15	
Iron	ppm	ASTM D5185m	>30	18	9	
Chromium	ppm	ASTM D5185m	>3	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>10	0	0	
Silver	ppm	ASTM D5185m		0	<1	
Aluminum	ppm	ASTM D5185m	>30	0	<1	
Lead	ppm	ASTM D5185m	>15	<1	<1	
Copper	ppm	ASTM D5185m	>10	0	<1	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	25	9	9	
Barium	ppm	ASTM D5185m	12	0	0	
Molybdenum	ppm	ASTM D5185m	5	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	25	0	<1	
Calcium	ppm	ASTM D5185m	25	21	17	
Phosphorus	ppm	ASTM D5185m	375	217	176	
Zinc	ppm	ASTM D5185m	25	3	3	
Sulfur	ppm	ASTM D5185m	4900	5677	4568	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+15	7	4	
Sodium	ppm	ASTM D5185m		4	2	
Potassium	ppm	ASTM D5185m	>20	0	1	
Water	%	ASTM D6304	>0.02	0.005	0.010	
ppm Water	ppm	ASTM D6304	>200	58.8	104.3	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		38115	23722	
Particles >6µm		ASTM D7647	>320	<u> </u>	△ 698	
Particles >14μm		ASTM D7647	>40	<u>^</u> 77	18	
Particles >21µm		ASTM D7647	>10	<u>^</u> 23	5	
Particles >38µm		ASTM D7647	>3	1	1	
Particles >71μm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/15/12	<u>22/18/13</u>	<u>22/17/11</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOU/a	VCTM DOUVE	1 10	0.26	0.21	



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: WC05739624 : 05739624

: 10294223

Diagnosed

Diagnostician : Jonathan Hester **Test Package**: IND 2 (Additional Tests: KF, PQ, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received

: 16 Jan 2023

: 17 Jan 2023

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL US 60606

Contact: DEVIN LINEHAN DLinehan@nordex-online.com

T: (312)386-4124 F: (312)386-7102

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)