




PROBLEM SUMMARY

Sample Rating Trend

ISO




Machine Id
AC1B (S/N 201511230030)
 Component
Compressor
 Fluid
SULLAIR SULLUBE (--- GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	MARGINAL
Particles >6µm	ASTM D7647	>2500	▲ 3476	1471	709
Particles >14µm	ASTM D7647	>320	▲ 398	233	61
Particles >21µm	ASTM D7647	>80	▲ 102	70	11
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 20/19/16	19/18/15	18/17/13

Customer Id: THRFAL
 Sample No.: USP235991
 Lab Number: 05739707
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

22 Feb 2019 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



06 Mar 2018 Diag: Doug Bogart

WATER



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



03 Jan 2018 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
AC1B (S/N 201511230030)

Component
Compressor
Fluid
SULLAIR SULLUBE (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP235991	USP179803	USP179795
Sample Date	Client Info		10 Jan 2023	22 Feb 2019	06 Mar 2018
Machine Age	hrs	Client Info	0	14337	10673
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			ATTENTION	NORMAL	MARGINAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	<1	<1
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m	<1	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	0	0	<1
Lead	ppm	ASTM D5185m >25	<1	0	2
Copper	ppm	ASTM D5185m >50	5	4	6
Tin	ppm	ASTM D5185m >15	2	0	<1
Antimony	ppm	ASTM D5185m	---	2	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	4
Barium	ppm	ASTM D5185m 745	557	698	665
Molybdenum	ppm	ASTM D5185m 0.0	0	<1	0
Manganese	ppm	ASTM D5185m	0	0	2
Magnesium	ppm	ASTM D5185m 0.0	4	<1	0
Calcium	ppm	ASTM D5185m 1	<1	2	0
Phosphorus	ppm	ASTM D5185m 3	0	<1	0
Zinc	ppm	ASTM D5185m 0.1	0	6	3
Sulfur	ppm	ASTM D5185m 240	153	232	188

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	2	0	<1
Sodium	ppm	ASTM D5185m	64	31	42
Potassium	ppm	ASTM D5185m >20	3	2	8
Water	%	ASTM D6304 >0.1	0.076	0.079	▲ 0.202
ppm Water	ppm	ASTM D6304 >1000	761.6	790	▲ 2020

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	8521	3473	2415
Particles >6µm	ASTM D7647	>2500	▲ 3476	1471	709
Particles >14µm	ASTM D7647	>320	▲ 398	233	61
Particles >21µm	ASTM D7647	>80	▲ 102	70	11
Particles >38µm	ASTM D7647	>20	5	1	0
Particles >71µm	ASTM D7647	>4	1	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 20/19/16	19/18/15	18/17/13


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 .06	0.50	0.250	0.404




OIL ANALYSIS REPORT


Particle Trend




Water




Acid Number



Water



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	38.1	40.9	39.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color

Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USP235991 Received : 16 Jan 2023
 Lab Number : 05739707 Diagnosed : 17 Jan 2023
 Unique Number : 10294306 Diagnostician : Doug Bogart
 Test Package : IND 2

3M - FAIRMONT
 710 NORTH STATE STREET
 FAIRMONT, MN
 US 56031
 Contact: JEFF NELSON
 jnelson2@mmm.com
 T: (507)235-2111
 F: (507)235-2180

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)