




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
TIMMINS TRANSPORT
 Component
Diesel Engine
 Fluid
SHELL ROTELLA T 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please note that this is a corrected copy for laboratory data update for particle count.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0584594	---	---
Sample Date	Client Info			09 Jan 2023	---	---
Machine Age	mls	Client Info		182089	---	---
Oil Age	mls	Client Info		20000	---	---
Oil Changed	Client Info			Not Changed	---	---
Sample Status				NORMAL	---	---

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>5		<1.0	---	---
Water	WC Method	>0.2		NEG	---	---
Glycol	WC Method			NEG	---	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	52	---	---
Chromium	ppm	ASTM D5185m	>20	1	---	---
Nickel	ppm	ASTM D5185m	>4	0	---	---
Titanium	ppm	ASTM D5185m		<1	---	---
Silver	ppm	ASTM D5185m	>3	0	---	---
Aluminum	ppm	ASTM D5185m	>20	7	---	---
Lead	ppm	ASTM D5185m	>40	17	---	---
Copper	ppm	ASTM D5185m	>330	9	---	---
Tin	ppm	ASTM D5185m	>15	2	---	---
Vanadium	ppm	ASTM D5185m		0	---	---
Cadmium	ppm	ASTM D5185m		0	---	---





ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	316	38	---	---
Barium	ppm	ASTM D5185m	0.0	0	---	---
Molybdenum	ppm	ASTM D5185m	1.2	43	---	---
Manganese	ppm	ASTM D5185m		1	---	---
Magnesium	ppm	ASTM D5185m	24	253	---	---
Calcium	ppm	ASTM D5185m	2292	1990	---	---
Phosphorus	ppm	ASTM D5185m	1064	870	---	---
Zinc	ppm	ASTM D5185m	1160	1063	---	---
Sulfur	ppm	ASTM D5185m	4996	2857	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	11	---	---
Sodium	ppm	ASTM D5185m		2	---	---
Potassium	ppm	ASTM D5185m	>20	22	---	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	0.6	---	---
Nitration	Abs/cm	*ASTM D7624	>20	12.1	---	---
Sulfation	Abs/.1mm	*ASTM D7415	>30	29.1	---	---



OIL ANALYSIS REPORT








FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	3428	---	---
Particles >6µm	ASTM D7647	>5000	1867	---	---
Particles >14µm	ASTM D7647	>640	318	---	---
Particles >21µm	ASTM D7647	>160	107	---	---
Particles >38µm	ASTM D7647	>40	17	---	---
Particles >71µm	ASTM D7647	>10	2	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	19/18/15	---	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414	>25	25.9	---	---
Base Number (BN)	mg KOH/g ASTM D2896	10.1	4.85	---	---

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	---	---
Yellow Metal	scalar *Visual	NONE	NONE	---	---
Precipitate	scalar *Visual	NONE	NONE	---	---
Silt	scalar *Visual	NONE	NONE	---	---
Debris	scalar *Visual	NONE	NONE	---	---
Sand/Dirt	scalar *Visual	NONE	NONE	---	---
Appearance	scalar *Visual	NORML	NORML	---	---
Odor	scalar *Visual	NORML	NORML	---	---
Emulsified Water	scalar *Visual	>0.2	NEG	---	---
Free Water	scalar *Visual		NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt ASTM D445	15.7	13.8	---	---

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0584594 Received : 17 Jan 2023
 Lab Number : **05741672** Tested : 19 Jan 2023
 Unique Number : 10296271 Diagnosed : 19 Jan 2023 - Doug Bogart
 Test Package : MOB 2 (Additional Tests: PrtCount)

ARKANSAS INDUSTRIAL MANUFACTURING
 NORTH 10141 HIGHWAY 63
 BONO, AR
 US 72416
 Contact: Aurelio Azpiazu
 aurelio@atfilters.com
 T: (202)674-4440
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)