

OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Machine Id **5547597 (S/N 1962)**

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Sep2021	Dec2022		
SAMPLE INFORM	//ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP52766	KCP37960	
Sample Date		Client Info		19 Dec 2022	07 Sep 2021	
Machine Age	hrs	Client Info		20378	16584	
Oil Age	hrs	Client Info		0	900	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ATTENTION	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	5	3	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	12	11	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	2	24	
Zinc	ppm	ASTM D5185m	0	18	2	
Sulfur	ppm	ASTM D5185m	23500	21750	19410	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	8	2	
Sodium	ppm	ASTM D5185m		2	2	
Potassium	ppm	ASTM D5185m	>20	0	<1	
Water	%	ASTM D6304	>0.05	0.012	0.010	
ppm Water	ppm	ASTM D6304	>500	124.9	101.4	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3614	1521	
Particles >6µm		ASTM D7647	>1300	1089	568	
Particles >14μm		ASTM D7647	>80	A 87	68	
Particles >21µm		ASTM D7647	>20	23	11	
Particles >38µm		ASTM D7647	>4	2	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/14	16/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

0.40

Page 1 of 2



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KCP52766 : 05742619 : 10297218

Recieved : 18 Jan 2023 Diagnosed

: 19 Jan 2023 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1111 JOELLIS WAY SACRAMENTO, CA US 95815

Contact: K. NEW knew@ellissigns.com

T: F: