

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO

Machine Id


# KAESER AS 20T 4998752 (S/N 1001)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

# COMPONENT CONDITION SUMMARY



### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		ABNORI	MAL ABNORMAL	ATTENTION					
Particles >6µm	ASTM D7647 >	<b>1</b> 300 <b>△ 2597</b>	▲ 3881	<u>1804</u>					
Particles >14µm	ASTM D7647 >	·80 <b>🔺 111</b>	<b>▲</b> 307	<u> </u>					
Particles >21µm	ASTM D7647 >	·20 <b>_ 24</b>	<u></u> 91	18					
Oil Cleanliness	ISO 4406 (c) >	/17/13 <b>A 20/19</b> /	<b>14</b> • 21/19/15	▲ 18/14					

Customer Id: CARIRV Sample No.: KCP52093 Lab Number: 05743607 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

### HISTORICAL DIAGNOSIS

### 02 Sep 2022 Diag: Don Baldridge





Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 24 May 2021 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 17 Dec 2020 Diag: Jonathan Hester

WEAR



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level is marginal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER AS 20T 4998752 (S/N 1001)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan 2019	Dec2020	May2021 Sep2022	Jan 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP52093	KCP50145	KCP35837
Sample Date		Client Info		05 Jan 2023	02 Sep 2022	24 May 2021
Machine Age	hrs	Client Info		33247	31742	26181
Oil Age	hrs	Client Info		0	3000	1910
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	5	11	48
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	1	0
Magnesium	ppm	ASTM D5185m	90	44	15	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		7	9	10
Zinc	ppm	ASTM D5185m		33	39	23
Sulfur	ppm	ASTM D5185m		19632	21621	16030
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	1
Sodium	ppm	ASTM D5185m		16	4	0
Potassium	ppm	ASTM D5185m	>20	3	0	<1
Water	%	ASTM D6304	>0.05	0.036	0.011	0.010
ppm Water	ppm	ASTM D6304	>500	360.6	119.6	104.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7771	10614	6472
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2597	▲ 3881	<u>▲</u> 1804
Particles >14µm		ASTM D7647	>80	<u> </u>	▲ 307	<u>^</u> 98
Particles >21µm		ASTM D7647	>20	<u>^</u> 24	<b>△</b> 91	18
Particles >38µm		ASTM D7647	>4	1	<u>^</u> 6	0
Particles >71µm		ASTM D7647	>3	0	1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/14	<u>\$\text{\Delta}\$ 21/19/15</u>	<u>▲</u> 18/14
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2

0.39



## **OIL ANALYSIS REPORT**

