




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
LGS00178

Component
Biogas Engine

Fluid
Q8 G8 MAHLER SAE 40 (141 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0660867	WC0660865	WC0660863
Sample Date	Client Info			17 Jan 2023	14 Dec 2022	07 Dec 2022
Machine Age	hrs	Client Info		59799	59114	58955
Oil Age	hrs	Client Info		110	282	595
Oil Changed	Client Info			N/A	Changed	N/A
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>4.0		<1.0	<1.0	<1.0
Glycol	WC Method			NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>45	3	8	4
Chromium	ppm	ASTM D5185m	>2	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>5	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	3	3
Lead	ppm	ASTM D5185m	>5	1	<1	<1
Copper	ppm	ASTM D5185m	>14	1	2	1
Tin	ppm	ASTM D5185m	>13	<1	2	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		6	5	8
Calcium	ppm	ASTM D5185m		2219	2098	1994
Phosphorus	ppm	ASTM D5185m		426	394	352
Zinc	ppm	ASTM D5185m		450	436	421
Sulfur	ppm	ASTM D5185m		3463	4115	2950




CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>200	53	115	54
Sodium	ppm	ASTM D5185m		<1	2	2
Potassium	ppm	ASTM D5185m	>20	2	0	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	5.0	5.6	6.1
Sulfation	Abs/.1mm	*ASTM D7415	>30	15.9	19.8	17.1

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	8.7	10.1	9.5
Acid Number (AN)	mg KOH/g	ASTM D8045		0.77	0.88	0.76
Base Number (BN)	mg KOH/g	ASTM D2896		5.94	5.56	6.17











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.1	13.3	13.2

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0660867 **Received** : 19 Jan 2023
Lab Number : 05744268 **Diagnosed** : 23 Jan 2023
Unique Number : 10298867 **Diagnostician** : Sean Felton
Test Package : MOB 2

BI-COUNTY
 3214 DOVER RD
 WOODLAWN, TN
 US 37191
 Contact: KEVIN WEAVER
 kevin.weaver@cubedistrictenergy.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)