



# FUEL REPORT

Sample Rating Trend

ISO



Area  
[20225676]

Machine Id  
Peerless 2141 K St Firepump

Component  
Diesel Fuel

Fluid  
NOT GIVEN (--- GAL)

## DIAGNOSIS

### Recommendation

Recommend pre-filter before use. All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur. ( Customer Sample Comment: 2141 k st Firepump fuel sample )

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is a high amount of particulates present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. No other contaminants were detected in the fuel.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			DC0014123	---	---
Sample Date	Client Info			03 Jan 2023	---	---
Machine Age	mths	Client Info		0	---	---
Sample Status				ATTENTION	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L4.5	---	---
Visc @ 40°C	cSt	ASTM D445		2.64	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		164	---	---
Sulfur (UVF)	ppm	ASTM D5453		207	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		35.6	---	---





CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	4	---	---
Sodium	ppm	ASTM D5185m	<0.1	<1	---	---
Potassium	ppm	ASTM D5185m	<0.1	0	---	---
Water	%	ASTM D6304	<0.05	0.004	---	---
ppm Water	ppm	ASTM D6304	<500	43.2	---	---
% Gasoline	%	*In-House	<0.50	0.0	---	---
% Biodiesel	%	*In-House	<20.0	0.0	---	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	▲ 57640	---	---
Particles >6µm		ASTM D7647	>640	▲ 21423	---	---
Particles >14µm		ASTM D7647	>80	▲ 2254	---	---
Particles >21µm		ASTM D7647	>20	▲ 737	---	---
Particles >38µm		ASTM D7647	>4	▲ 52	---	---
Particles >71µm		ASTM D7647	>3	2	---	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ 23/22/18	---	---

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	---	---
Nickel	ppm	ASTM D5185m	<0.1	0	---	---
Lead	ppm	ASTM D5185m	<0.1	<1	---	---
Vanadium	ppm	ASTM D5185m	<0.1	0	---	---
Iron	ppm	ASTM D5185m	<0.1	<1	---	---
Calcium	ppm	ASTM D5185m	<0.1	0	---	---
Magnesium	ppm	ASTM D5185m	<0.1	<1	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	28	---	---
Zinc	ppm	ASTM D5185m	<0.1	3	---	---




# FUEL REPORT



## SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : DC0014123 **Received** : 19 Jan 2023  
**Lab Number** : **05744358** **Diagnosed** : 31 Jan 2023  
**Unique Number** : 10298957 **Diagnostician** : Doug Bogart  
**Test Package** : DF-5 ( Additional Tests: API, Cetane, Fuel, Screen )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**JE RICHARDS**  
 4600 HARGROVE DR  
 LANHAM, MD  
 US 20706  
 Contact: E. NOEL  
 enoel@phalconusa.com  
 T: (240)623-4398  
 F: