




PROBLEM SUMMARY


Area
Recovery
 Machine Id
Bornemann FHG25BP01 Decanter, Sludge Outlet Flow Pump
 Component
Gearbox
 Fluid
JAX Flow-Guard Synthetic 100 (4 QTS)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ 110701	---	---
Particles >6µm	ASTM D7647	>5000	▲ 39200	---	---
Particles >14µm	ASTM D7647	>640	▲ 735	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/22/17	---	---

Customer Id: NOVFRANC
 Sample No.: WC0765175
 Lab Number: 05746162
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	SKIPPED	Jun 05 2023	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Check Breathers	SKIPPED	Jun 05 2023	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Filter Fluid	SKIPPED	Jun 05 2023	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

03 May 2022 Diag: Angela Borella

WEAR



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



15 Mar 2022 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. Gear wear is indicated. There is a moderate concentration of water present in the oil. There is a high amount of visible silt present in the sample. The AN level is acceptable for this fluid.

view report



15 Feb 2022 Diag: Jonathan Hester

WEAR



We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. Please note that there was too much water present in the oil to perform a viscosity test. Gear wear is indicated. Appearance is milky. Excessive free water present. There is a high concentration of water present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. Moderate concentration of visible dirt/debris present in the oil. The oil is no longer serviceable due to the presence of contaminants.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

Recovery

Machine Id

Bornemann FHG25BP01 Decanter, Sludge Outlet Flow Pump

Component

Gearbox

Fluid

JAX Flow-Guard Synthetic 100 (4 QTS)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0765175	WC0660557	WC0656548
Sample Date	Client Info	20 Jan 2023	03 May 2022	15 Mar 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	6	▲ 502	▲ 385
Chromium	ppm	ASTM D5185m >15	<1	8	4
Nickel	ppm	ASTM D5185m >15	<1	0	0
Titanium	ppm	ASTM D5185m	0	<1	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	0	3	7
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >200	0	6	8
Tin	ppm	ASTM D5185m >25	<1	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	4
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0
Manganese	ppm	ASTM D5185m	0	3	2
Magnesium	ppm	ASTM D5185m	1	0	0
Calcium	ppm	ASTM D5185m	1	4	5
Phosphorus	ppm	ASTM D5185m	124	89	128
Zinc	ppm	ASTM D5185m	0	17	11
Sulfur	ppm	ASTM D5185m	1720	1442	1438

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	5	4	6
Sodium	ppm	ASTM D5185m	<1	0	0
Potassium	ppm	ASTM D5185m >20	<1	2	0
Chlorine	ppm	ASTM D5185m	---	---	---
Water	%	ASTM D6304 >0.2	0.008	0.001	▲ 0.733
ppm Water	ppm	ASTM D6304 >2000	85.7	3.6	▲ 7330

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 110701	---	---
Particles >6µm	ASTM D7647 >5000	▲ 39200	---	---
Particles >14µm	ASTM D7647 >640	▲ 735	---	---
Particles >21µm	ASTM D7647 >160	86	---	---
Particles >38µm	ASTM D7647 >40	2	---	---
Particles >71µm	ASTM D7647 >10	0	---	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 24/22/17	---	---


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.32	0.22	0.15




OIL ANALYSIS REPORT


Particle Trend




Water




Acid Number



Water



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	LIGHT	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	▲ VHEVY
Debris	scalar	*Visual	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	▲ 0.2%
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	100.0	100	107	110

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0765175 **Received** : 23 Jan 2023
Lab Number : 05746162 **Diagnosed** : 25 Jan 2023
Unique Number : 10305766 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

NOVOZYMES
 P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD
 FRANKLINTON, NC
 US 27525
 Contact: BRUCE THOMAS
 brct@novozymes.com
 T: (919)494-3146
 F: (919)494-3456

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)