

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


1348743 (S/N 1312)

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL					
Particles >6μm	ASTM D7647	>1300	<u> </u>						
Particles >14µm	ASTM D7647	>80	<b>2017</b>						
Particles >21µm	ASTM D7647	>20	<b>△</b> 66						
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>25/24/18</b>						

Customer Id: BRAEASMA Sample No.: KCP52054 Lab Number: 05746201 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Oil and filter change at the time of sampling has been noted.			
Change Filter			?	Oil and filter change at the time of sampling has been noted.			

## HISTORICAL DIAGNOSIS

## 23 Jul 2021 Diag: Don Baldridge

WATER




Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.





# **OIL ANALYSIS REPORT**



1348743 (S/N 1312)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

						\
			Jul2021	Jan 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP52054	KCP42059	
Sample Date		Client Info		10 Jan 2023	23 Jul 2021	
Machine Age	hrs	Client Info		91104	87291	
Oil Age	hrs	Client Info		3813	382	
Oil Changed	1110	Client Info		Changed	Changed	
Sample Status		Oliciti IIIIo		ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	nnm		>50	4	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead		ASTM D5185m	>10	0	<1	
	ppm	ASTM D5185m	>50	14	4	
Copper Tin	ppm	ASTM D5185m			0	
	ppm	ASTM D5185m	>10	<1		
Antimony Vanadium	ppm				0	
	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		1	12	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		3	9	
Calcium	ppm	ASTM D5185m		<1	<1	
Phosphorus	ppm	ASTM D5185m	500	223	234	
Zinc	ppm	ASTM D5185m		265	84	
Sulfur	ppm	ASTM D5185m		451	6640	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	<1	
Sodium	ppm	ASTM D5185m		0	<1	
Potassium	ppm	ASTM D5185m	>20	2	<1	
Water	%	ASTM D6304	>0.05	0.004	<b>△</b> 0.580	
ppm Water	ppm	ASTM D6304	>500	45.2	▲ 5800	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		188406		
Particles >6µm		ASTM D7647	>1300	<b>121138</b>		
Particles >14µm		ASTM D7647	>80	<u>△</u> 2017		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	△ 25/24/18		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)


mg KOH/g ASTM D8045 1.5

Contact/Location: S GOUPIL - BRAEASMA

0.893



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** 

: KCP52054

: 05746201 : 10305805

Received : 23 Jan 2023 Diagnosed : 25 Jan 2023 Diagnostician : Don Baldridge

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

To discuss this sample report, contact Customer Service at 1-800-237-1369.

SGOUPIL@BRADYENTERPRISES.COM

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 02189

T: F:

EAST WEYMOUTH, MA

Contact: S GOUPIL