


PROBLEM SUMMARY

Sample Rating Trend



WATER


7319974 (S/N 1526)

Component

Compressor

CAS M-460 (2 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE				
Water	%	ASTM D6304	>0.05	<u> </u>				
ppm Water	ppm	ASTM D6304	>500	4 3510				
Silt	scalar	*Visual	NONE	▲ MODER				
Emulsified Water	scalar	*Visual	>0.05	0.2%				
Free Water	scalar	*Visual		5.0				

Customer Id: CASERIPA **Sample No.:** WC0781042 Lab Number: 05748974 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	We recommend an early resample to monitor this condition.			
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.			
Check Water Access			?	We advise that you check for the source of water entry.			

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT


Acid Number (AN)

mg KOH/g ASTM D8045

7319974 (S/N 1526) Component

Compressor

CAS M-460 (2 GAL)





DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Appearance is milky. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. Excessive free water present.

Fluid Condition


The AN level is acceptable for this fluid.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0781042		
Sample Date		Client Info		19 Jan 2023		
Machine Age	hrs	Client Info		841		
Oil Age	hrs	Client Info		841		
Oil Changed		Client Info		Not Changd		
Sample Status				SEVERE		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m	>10	1		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		7		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		36		
Calcium	ppm	ASTM D5185m		5		
Phosphorus	ppm	ASTM D5185m		55		
Zinc	ppm	ASTM D5185m		36		
Sulfur	ppm	ASTM D5185m		21423		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		5		
Potassium	ppm	ASTM D5185m	>20	8		
Water	%	ASTM D6304	>0.05	<u> </u>		
ppm Water	ppm	ASTM D6304	>500	<u>▲</u> 3510		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A siel Nivershau (ANI)	I/OII/-	ACTM DODAE		0.04		

0.34



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

: 05748974 Unique Number: 10308578

: WC0781042

Received **Tested** Diagnosed

: 24 Jan 2023 : 26 Jan 2023

: 26 Jan 2023 - Don Baldridge

2022 FILMORE AVENUE ERIE, PA US 16506

Test Package: IND 2 (Additional Tests: KF, PrtCount) Contact: Phil Shaver To discuss this sample report, contact Customer Service at 1-800-237-1369. pshaver@cascousa.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: CASERIPA [WUSCAR] 05748974 (Generated: 02/19/2024 14:19:55) Rev: 1

Contact/Location: Phil Shaver - CASERIPA

T:

F: