

# **PROBLEM SUMMARY**

### Sample Rating Trend



30-5 FRICK ER2 (S/N N11)


Component

**Refrigeration Compressor** 

USPI ALT-68 SC (140 GAL)



## **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL	SEVERE				
Particles >4μm	ASTM D7647	>10000	<u> </u>	<u>^</u> 203473	112358				
Particles >6µm	ASTM D7647	>2500	<b>26374</b>	<b>▲</b> 79023	18570				
Oil Cleanliness	ISO 4406 (c)	>20/18/16	<u>4</u> 24/22/15	<u>\$\Delta\$ 25/23/16</u>	<b>2</b> 4/21/15				

Customer Id: KRANEW\_USP
Sample No.: USP244070
Lab Number: 05749555
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

# 11 Jul 2022 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. An increase in the iron level is noted. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 12 May 2022 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 13 Apr 2022 Diag: Doug Bogart

150



Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 30-5 FRICK ER2 (S/N N11)

Componen

**Refrigeration Compressor** 

USPI ALT-68 SC (140 GAL)

## DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		ct2015 Oct20	16 Jul2017 Apr2018	Nov2018 Jul2020 Jan2021 Apr	2022 Jan207	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP244070	USP233455	USP231005
Sample Date		Client Info		19 Jan 2023	11 Jul 2022	12 May 2022
Machine Age	hrs	Client Info		33189	31890	30738
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	6	26	6
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		1	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	<1	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	0	3	3
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	0	0
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304	>0.01	0.003	0.004	0.003
ppm Water	ppm	ASTM D6304	>100	29.9	46.2	35.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>119304</b>	<b>2</b> 03473	112358
Particles >6µm		ASTM D7647	>2500	<b>^</b> 26374	<b>▲</b> 79023	<b>18570</b>
Particles >14µm		ASTM D7647	>640	184	631	271
Particles >21µm		ASTM D7647	>160	25	28	32
Particles >38µm		ASTM D7647	>40	4	0	0
Particles >71µm		ASTM D7647	>10	3	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	<u>4</u> 24/22/15	<u>△</u> 25/23/16	<b>2</b> 4/21/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.015	0.015	0.014



# **OIL ANALYSIS REPORT**





: 10309159 To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

**Unique Number** 

Test Package

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

: Jonathan Hester

Certificate L2367

US 29108

Contact:

T: F: