



# OIL ANALYSIS REPORT


Sample Rating Trend

**NORMAL**



## Machine Id **VACUUM DEGASSER PUMP**

Component  
**New (Unused) Oil**  
Fluid  
**LEYBONOL LVO 120 (15000 GAL)**



### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please note that this is a corrected copy for data entry updates.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0758503</b>	---	---
Sample Date	Client Info	<b>20 Jan 2023</b>	---	---
Machine Age	hrs Client Info	<b>0</b>	---	---
Oil Age	hrs Client Info	<b>0</b>	---	---
Oil Changed	Client Info	<b>Not Chngd</b>	---	---
Sample Status		<b>NORMAL</b>	---	---

### WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>5	<b>0</b>	---	---
Chromium ppm ASTM D5185m	>5	<b>0</b>	---	---
Nickel ppm ASTM D5185m	>5	<b>0</b>	---	---
Titanium ppm ASTM D5185m		<b>0</b>	---	---
Silver ppm ASTM D5185m	>5	<b>0</b>	---	---
Aluminum ppm ASTM D5185m	>5	<b>0</b>	---	---
Lead ppm ASTM D5185m	>5	<b>0</b>	---	---
Copper ppm ASTM D5185m	>5	<b>0</b>	---	---
Tin ppm ASTM D5185m	>5	<b>0</b>	---	---
Vanadium ppm ASTM D5185m		<b>0</b>	---	---
Cadmium ppm ASTM D5185m		<b>0</b>	---	---

### ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m		<b>0</b>	---	---
Barium ppm ASTM D5185m		<b>0</b>	---	---
Molybdenum ppm ASTM D5185m		<b>0</b>	---	---
Manganese ppm ASTM D5185m		<b>0</b>	---	---
Magnesium ppm ASTM D5185m		<b>0</b>	---	---
Calcium ppm ASTM D5185m		<b>58</b>	---	---
Phosphorus ppm ASTM D5185m		<b>373</b>	---	---
Zinc ppm ASTM D5185m		<b>461</b>	---	---
Sulfur ppm ASTM D5185m		<b>5684</b>	---	---

### CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>15	<b>&lt;1</b>	---	---
Sodium ppm ASTM D5185m		<b>&lt;1</b>	---	---
Potassium ppm ASTM D5185m	>20	<b>0</b>	---	---
Water % ASTM D6304		<b>0.003</b>	---	---
ppm Water ppm ASTM D6304		<b>29.4</b>	---	---

### FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm ASTM D7647	>5000	<b>650</b>	---	---
Particles >6µm ASTM D7647	>1300	<b>97</b>	---	---
Particles >14µm ASTM D7647	>160	<b>2</b>	---	---
Particles >21µm ASTM D7647	>40	<b>1</b>	---	---
Particles >38µm ASTM D7647	>10	<b>0</b>	---	---
Particles >71µm ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness ISO 4406 (c)	>19/17/14	<b>17/14/9</b>	---	---

### FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D8045		<b>0.62</b>	---	---




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	NEG	---	---
Free Water	scalar	*Visual	NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32.3	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0758503 **Received** : 26 Jan 2023  
**Lab Number** : 05751402 **Diagnosed** : 01 Aug 2023  
**Unique Number** : 10311006 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**GENERAL MOTORS VPC BUILDING**  
 30003 VAN DYKE AVE.  
 WARREN, MI  
 US 48090  
 Contact: DANIEL BARKUME  
 daniel.barkume@gm.com  
 T: (586)489-5310  
 F: (586)575-1675

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)