




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
GZJ00314
 Component
Biogas Engine
 Fluid
PETRO CANADA SENTRON CG 40 (145 GAL)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. (Customer Sample Comment: Total oil added 19 gal)

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0699003	WC0698998	WC0699010
Sample Date	Client Info		24 Jan 2023	17 Jan 2023	03 Jan 2023
Machine Age	hrs	Client Info	120344	120184	119878
Oil Age	hrs	Client Info	81	923	617
Oil Changed		Client Info	N/A	N/A	N/A
Sample Status			NORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >45	2	12	7
Chromium	ppm	ASTM D5185m >2	<1	<1	<1
Nickel	ppm	ASTM D5185m >2	<1	<1	0
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m >5	0	0	0
Aluminum	ppm	ASTM D5185m >10	1	4	4
Lead	ppm	ASTM D5185m >5	1	2	<1
Copper	ppm	ASTM D5185m >14	<1	4	4
Tin	ppm	ASTM D5185m >13	2	8	6
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	<1	0
Barium	ppm	ASTM D5185m 1	0	0	0
Molybdenum	ppm	ASTM D5185m 2	<1	2	1
Manganese	ppm	ASTM D5185m 1	<1	<1	<1
Magnesium	ppm	ASTM D5185m 9	14	18	14
Calcium	ppm	ASTM D5185m 2712	3034	3514	3115
Phosphorus	ppm	ASTM D5185m 292	310	362	293
Zinc	ppm	ASTM D5185m 342	371	432	344
Sulfur	ppm	ASTM D5185m 2575	3953	4782	3735

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >200	83	▲ 450	▲ 343
Sodium	ppm	ASTM D5185m	<1	4	<1
Potassium	ppm	ASTM D5185m >20	<1	<1	0
Fuel	%	ASTM D3524 >4.0	0.4	0.4	0.3

INFRA-RED





	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >20	4.4	6.5	5.8
Sulfation	Abs/.1mm	*ASTM D7415 >30	15.3	22.8	20.6

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	8.4	15.5	12.7
Acid Number (AN)	mg KOH/g	ASTM D8045 0.98	0.65	1.41	1.23
Base Number (BN)	mg KOH/g	ASTM D2896 8.1	7.90	6.07	7.00











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.9	13.7

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0699003 **Received** : 27 Jan 2023
Lab Number : 05752300 **Tested** : 30 Jan 2023
Unique Number : 10311904 **Diagnosed** : 30 Jan 2023 - Sean Felton
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

FINLEY BIOENERGY
 74265 Bombing Range Road
 Boardman, OR
 US 97818
 Contact: Blain Middleton
 bmiddleton@archaea.energy
 T: (541)481-3232
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)