

OIL ANALYSIS REPORT

Sample Rating Trend



Molding PRESS 37 (S/N 81660107)

Hydraulic System

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Dec2022		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		ST40984		
Sample Date		Client Info		15 Dec 2022		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	0		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>20	<1		
Tin	ppm	ASTM D5185m	>20	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		99		
Phosphorus	ppm	ASTM D5185m		390		
Zinc	ppm	ASTM D5185m		15		
Sulfur	ppm	ASTM D5185m		1935		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	1		
Water	%	ASTM D6304	>0.05	0.007		
ppm Water	ppm	ASTM D6304	>500	74.6		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>5000	363		
Particles >6µm		ASTM D7647	>1300	116		
Particles >14μm		ASTM D7647	>160	12		
Particles >21µm		ASTM D7647	>40	4		
Particles >38µm		ASTM D7647	>10	1		
Particles >71µm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	16/14/11		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.081		



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 05753580

: ST40984

Unique Number : 10313184

Received : 30 Jan 2023 **Tested**

: 31 Jan 2023 Diagnosed Test Package : IND 2 (Additional Tests: KF)

: 31 Jan 2023 - Don Baldridge To discuss this sample report, contact Customer Service at 1-800-237-1369.

US 07463 Contact: Jonathan Vanbeekum jonathan.vanbeekum@menshen.com

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: MENWAL [WUSCAR] 05753580 (Generated: 05/14/2024 14:13:36) Rev: 1

Contact/Location: Jonathan Vanbeekum - MENWAL

T:

F:

21 INDUSTRIAL PARK

WALDWICK, NJ