




FUEL REPORT

Sample Rating Trend



VIS DEBRIS



Machine Id
USF MDH
Component
Diesel Fuel
Fluid
OFF-ROAD (2000 GAL)

DIAGNOSIS

▲ Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. All other laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur.

Corrosion

All metal levels are normal indicating no corrosion in the system.

▲ Contaminants

Moderate concentration of visible dirt/debris present in the fuel. There is no Bacteria, Yeast and/or Fungus indicated in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D4294 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WCDF04294	WCDF04372	WCDF04447
Sample Date	Client Info			27 Jan 2023	03 Feb 2022	14 Dec 2021
Machine Age	mls	Client Info		0	0	0
Sample Status				ATTENTION	NORMAL	ABNORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.839	---	0.844
Fuel Color	text	*Visual Screen		Orang	---	Red
ASTM Color	scalar	*ASTM D1500		1.0	3.0	L4.0
Visc @ 40°C	cSt	ASTM D445		2.46	2.46	2.5
Pensky-Martens Flash Point	°C	*PMCC Calculated		61	---	61
Cloud Point	°C	ASTM D5771		-12	---	-14

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0	108	70
Sulfur (UVF)	ppm	ASTM D5453		39	78	100




DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		169	---	164
5% Distillation Point	°C	ASTM D86		192	---	195
10% Distill Point	°C	ASTM D86		202	---	205
15% Distillation Point	°C	ASTM D86		209	---	213
20% Distill Point	°C	ASTM D86		217	---	220
30% Distill Point	°C	ASTM D86		232	---	233
40% Distill Point	°C	ASTM D86		244	---	245
50% Distill Point	°C	ASTM D86		259	---	258
60% Distill Point	°C	ASTM D86		273	---	271
70% Distill Point	°C	ASTM D86		287	---	285
80% Distill Point	°C	ASTM D86		303	---	301
85% Distillation Point	°C	ASTM D86		312	---	310
90% Distill Point	°C	ASTM D86		324	---	321
95% Distillation Point	°C	ASTM D86		342	---	338
Final Boiling Point	°C	ASTM D86		349	---	343
Distillation Residue	%	ASTM D86		1.4	---	1.4
Distillation Loss	%	ASTM D86		0.7	---	0.4

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37.2	---	36.2
Cetane Index		ASTM D4737	<40.0	48.6	---	46.6

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	0
Sodium	ppm	ASTM D5185m	<0.1	0	0	0
Potassium	ppm	ASTM D5185m	<0.1	0	0	<1
Water	%	ASTM D6304	<0.05	0.008	0.011	0.011
ppm Water	ppm	ASTM D6304	<500	88.9	110.1	111.5
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.8	0.0





FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	<1	0
Nickel	ppm	ASTM D5185m	<0.1	0	0	0
Lead	ppm	ASTM D5185m	<0.1	0	0	0
Vanadium	ppm	ASTM D5185m	<0.1	0	0	0
Iron	ppm	ASTM D5185m	<0.1	<1	2	1
Calcium	ppm	ASTM D5185m	<0.1	0	0	0
Magnesium	ppm	ASTM D5185m	<0.1	0	0	<1
Phosphorus	ppm	ASTM D5185m	<0.1	4	3	5
Zinc	ppm	ASTM D5185m	<0.1	0	0	0

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WCDF04294 **Received** : 01 Feb 2023
Lab Number : 05756539 **Diagnosed** : 08 Feb 2023
Unique Number : 10321146 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: CldPt, Screen)

TANK WIZARDS
 1511 MASTERS RD NW
 PALM BAY, FL
 US 32907
 Contact: WENDALL STRODERD
 wendall@tankwizards.com
 T: (321)427-5149
 F: (321)574-4131

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)