




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
FL-3
 Component
Diesel Engine
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|----------|
| Sample Number | Client Info | | | WC0721340 | WC0469003 | --- |
| Sample Date | Client Info | | | 12 Jan 2023 | 26 Oct 2020 | --- |
| Machine Age | hrs | Client Info | | 2727 | 2464 | --- |
| Oil Age | hrs | Client Info | | 400 | 500 | --- |
| Oil Changed | Client Info | | | Changed | Changed | --- |
| Sample Status | | | | NORMAL | ATTENTION | --- |

| CONTAMINATION | | method | limit/base | current | history1 | history2 |
|---------------|-----------|--------|------------|------------|----------|----------|
| Glycol | WC Method | | | NEG | NEG | --- |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | >100 | 73 | 68 | --- |
| Chromium | ppm | ASTM D5185m | >20 | 13 | 7 | --- |
| Nickel | ppm | ASTM D5185m | >2 | 0 | 0 | --- |
| Titanium | ppm | ASTM D5185m | >2 | <1 | <1 | --- |
| Silver | ppm | ASTM D5185m | >2 | 0 | <1 | --- |
| Aluminum | ppm | ASTM D5185m | >25 | 5 | 2 | --- |
| Lead | ppm | ASTM D5185m | >40 | 7 | 3 | --- |
| Copper | ppm | ASTM D5185m | >330 | 4 | 3 | --- |
| Tin | ppm | ASTM D5185m | >15 | 4 | 1 | --- |
| Antimony | ppm | ASTM D5185m | | --- | 0 | --- |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | --- |
| Cadmium | ppm | ASTM D5185m | | 2 | 1 | --- |

| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | | 16 | 3 | --- |
| Barium | ppm | ASTM D5185m | | 0 | 0 | --- |
| Molybdenum | ppm | ASTM D5185m | | 26 | 2 | --- |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | --- |
| Magnesium | ppm | ASTM D5185m | | 570 | 17 | --- |
| Calcium | ppm | ASTM D5185m | | 1396 | 1258 | --- |
| Phosphorus | ppm | ASTM D5185m | | 736 | 620 | --- |
| Zinc | ppm | ASTM D5185m | | 917 | 660 | --- |
| Sulfur | ppm | ASTM D5185m | | 3331 | 3253 | --- |




| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|----------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | 9 | 9 | --- |
| Sodium | ppm | ASTM D5185m | | 48 | ▲ 231 | --- |
| Potassium | ppm | ASTM D5185m | >20 | 2 | 3 | --- |
| Fuel | % | ASTM D3524 | >5 | <1.0 | 0.2 | --- |

| INFRA-RED | | method | limit/base | current | history1 | history2 |
|-----------|----------|-------------|------------|-------------|----------|----------|
| Soot % | % | *ASTM D7844 | >3 | 0.1 | 0 | --- |
| Nitration | Abs/cm | *ASTM D7624 | >20 | 10.1 | 8 | --- |
| Sulfation | Abs/.1mm | *ASTM D7415 | >30 | 20.7 | 19.8 | --- |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|-------------|------------|-------------|----------|----------|
| Oxidation | Abs/.1mm | *ASTM D7414 | >25 | 15.9 | 10 | --- |
| Base Number (BN) | mg KOH/g | ASTM D2896 | | 7.90 | 3.28 | --- |











OIL ANALYSIS REPORT



| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- |
| Silt | scalar | *Visual | NONE | NONE | --- |
| Debris | scalar | *Visual | NONE | NONE | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- |
| Odor | scalar | *Visual | NORML | NORML | --- |
| Emulsified Water | scalar | *Visual | >0.2 | NEG | --- |
| Free Water | scalar | *Visual | | NEG | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|-------------|----------|----------|
| Visc @ 100°C | cSt | ASTM D445 | 13.4 | ▲ 9.4 | --- |

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0721340 **Received** : 02 Feb 2023
Lab Number : **05757848** **Diagnosed** : 06 Feb 2023
Unique Number : 10322455 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

TRESCA BROS SAND & GRAVEL INC
 66 MAIN ST
 MILLIS, MA
 US 02054

Contact: FRAN ROSSI
 frossi@trescaconcrete.com
 T: (508)376-2957
 F: (508)376-4333

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)