


PROBLEM SUMMARY


BATCH SYSTEM 5 Machine Id BS5 HOMO GEARBOX

Component **Gearbox**

SCHAEFFER ISO 460 (--- LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ATTENTION					
Particles >4μm	ASTM D7647	>20000	<u> </u>	<u>▲</u> 27332					
Particles >6μm	ASTM D7647	>5000	59452	1907					
Particles >14μm	ASTM D7647	>640	12630	92					
Particles >21μm	ASTM D7647	>160	1533	23					
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<u>4</u> 24/23/21	<u>22/18/14</u>					

Customer Id: KRAMASIOW Sample No.: USP234431 Lab Number: 05762093 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	SKIPPED	May 17 2023	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

18 Aug 2022 Diag: Jonathan Hester





Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is a moderate amount of silt (particulates < 6 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

BATCH SYSTEM 5 **BS5** HOMO GEARBOX

Gearbox

SCHAEFFER ISO 460 (--- LTR)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Aug2022	Feb 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP234431	USP232478	
Sample Date		Client Info		01 Feb 2023	18 Aug 2022	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	1	11	
Chromium	ppm	ASTM D5185m	>15	0	0	
Nickel	ppm	ASTM D5185m	>15	0	0	
Titanium	ppm	ASTM D5185m		0	<1	
Silver	ppm	ASTM D5185m		0	<1	
Aluminum	ppm	ASTM D5185m	>25	0	<1	
Lead	ppm	ASTM D5185m	>100	0	0	
Copper	ppm	ASTM D5185m	>200	0	2	
Tin	ppm		>25	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		65	110	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		2	18	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		<1	6	
Calcium	ppm	ASTM D5185m		2	36	
Phosphorus	ppm	ASTM D5185m		259	724	
Zinc	ppm	ASTM D5185m		7	36	
Sulfur	ppm	ASTM D5185m		6666	20193	
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	5	12	
Sodium	ppm	ASTM D5185m		<1	3	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.2	0.008	0.005	
ppm Water	ppm	ASTM D6304	>2000	87.3	58.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>20000	<u> </u>	▲ 27332	
Particles >6µm		ASTM D7647	>5000	59452	1907	
Particles >14µm		ASTM D7647	>640	12630	92	
Particles >21µm		ASTM D7647	>160	<u> </u>	23	
Particles >38µm		ASTM D7647	>40	8	1	
Particles >71µm		ASTM D7647	>10	0	0	
Oil Cleanliness		ISO 4406 (c)	>21/19/16	24/23/21	<u>22/18/14</u>	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (ANI)	ma 1/011/a	ACTM DODAE		0.54	1.00	

Acid Number (AN)


mg KOH/g ASTM D8045

1.68

0.54



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package

: USP234431 : 05762093

Received : 10331701

: 08 Feb 2023 Diagnosed : 09 Feb 2023 Diagnostician : Doug Bogart KraftHeinz - Mason City - Plant 8360

1022 12TH ST MASON CITY, IA US 50401

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (641)421-2936

T: