

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


KAESER 7171453

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		ATTENTION	NORMAL	ABNORMAL					
Particles >6µm	ASTM D7647 >13	00 <b>42462</b>	1165	<b>△</b> 6096					
Particles >14µm	ASTM D7647 >80	<b>127</b>	36	<u></u> 538					
Oil Cleanliness	ISO 4406 (c) >/	7/13 <b>A 20/18/14</b>	19/17/12	<b>2</b> 0/16					

Customer Id: AMAGAR Sample No.: KCP55917 Lab Number: 05766631 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

### HISTORICAL DIAGNOSIS

### 16 Jun 2022 Diag: Don Baldridge

### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 21 Feb 2022 Diag: Don Baldridge

150



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

# view report

### 06 Oct 2021 Diag: Jonathan Hester

ISO




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# **KAESER 7171453**

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec2020	0ct2021	Feb 2022 Jun 2022	Feb 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP55917	KCP41342	KCP41177
Sample Date		Client Info		07 Feb 2023	16 Jun 2022	21 Feb 2022
Machine Age	hrs	Client Info		14046	8353	8660
Oil Age	hrs	Client Info		3823	1764	1855
Oil Changed		Client Info		Changed	Not Changd	Changed
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	2	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	1	0
Barium	ppm	ASTM D5185m	90	0	22	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	0	61	72
Calcium	ppm	ASTM D5185m	2	0	1	0
Phosphorus	ppm	ASTM D5185m		7	4	2
Zinc	ppm	ASTM D5185m		0	7	2
Sulfur	ppm	ASTM D5185m		20963	19245	17301
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	2	<1
Sodium	ppm	ASTM D5185m		0	15	11
Potassium	ppm	ASTM D5185m	>20	0	2	0
Water	%	ASTM D6304	>0.05	0.007	0.015	0.021
ppm Water	ppm	ASTM D6304	>500	70.7	157.4	216.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8900	3962	15819
Particles >6μm		ASTM D7647	>1300	<u>^</u> 2462	1165	▲ 6096
Particles >14μm		ASTM D7647	>80	<u> </u>	36	<u></u> 538
Particles >21µm		ASTM D7647	>20	24	8	<b>▲</b> 89
Particles >38μm		ASTM D7647	>4	0	0	<b>▲</b> 5
Particles >71μm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/14	19/17/12	<u>^</u> 20/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.40

0.38



# OIL ANALYSIS REPORT

