




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
KAESER 5425369

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCP52481	KCP46544D	KCP22913
Sample Date	Client Info			31 Jan 2023	20 Oct 2022	20 Jul 2020
Machine Age	hrs	Client Info		62551	60080	40375
Oil Age	hrs	Client Info		3600	6401	4436
Oil Changed	Client Info			Changed	Changed	Changed
Sample Status				NORMAL	ATTENTION	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	3
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	16	36	28
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m		---	---	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	3
Barium	ppm	ASTM D5185m	90	67	38	<1
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	71	44	6
Calcium	ppm	ASTM D5185m	0	2	<1	0
Phosphorus	ppm	ASTM D5185m	0	5	9	35
Zinc	ppm	ASTM D5185m	0	39	26	104
Sulfur	ppm	ASTM D5185m	23500	17297	19494	15108

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	6
Sodium	ppm	ASTM D5185m		14	<1	2
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.05	0.011	0.002	0.005
ppm Water	ppm	ASTM D6304	>500	117.0	21.7	55.5

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2144	7314	22971
Particles >6µm		ASTM D7647	>1300	558	▲ 1498	▲ 3347
Particles >14µm		ASTM D7647	>80	43	72	▲ 84
Particles >21µm		ASTM D7647	>20	15	14	11
Particles >38µm		ASTM D7647	>4	1	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	18/16/13	▲ 20/18/13	▲ 19/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39	0.44	0.512


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.2	51.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP52481 **Received** : 15 Feb 2023
Lab Number : 05768132 **Tested** : 16 Feb 2023
Unique Number : 10337740 **Diagnosed** : 16 Feb 2023 - Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PrtCount)

SGS NORTH AMERICA INC
 4665 PARIS ST, SUITE 100A
 DENVER, CO
 US 80239
 Contact: AUBREY ASPEN
 aubrey.aspen@sgs.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)