


FUEL REPORT

{UNASSIGNED} Machine Id KIOTI PX1153 Kioti (S/N SX9700008)

Diesel Fuel

NOT GIVEN (--- GAL)





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low sulfur diesel fuel. (Customer Sample Comment: Need diesel fuel sample done)

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no Bacteria, Yeast and/or Fungus indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

				Feb 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KT0000224		
Sample Date		Client Info		10 Feb 2023		
Machine Age	hrs	Client Info		1563		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.825		
Fuel Color	text	*Visual Screen		Yllow		
ASTM Color	scalar	*ASTM D1500		2.0		
Visc @ 40°C	cSt	ASTM D445		2.57		
Pensky-Martens Flash Point	°C	*PMCC Calculated		62		
SULFUR CONTER	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		6		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		170		
5% Distillation Point	°C	ASTM D86		194		
10% Distill Point	°C	ASTM D86		207		
15% Distillation Point	°C	ASTM D86		216		
20% Distill Point	°C	ASTM D86		225		
30% Distill Point	°C	ASTM D86		240		
40% Distill Point	°C	ASTM D86		254		
50% Distill Point	°C	ASTM D86		268		
60% Distill Point	°C	ASTM D86		280		
70% Distill Point	°C	ASTM D86		293		
80% Distill Point	°C	ASTM D86		307		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86		325		
95% Distillation Point	°C	ASTM D86		341		
Final Boiling Point	°C	ASTM D86		349		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.9		
IGNITION QUALIT	ГҮ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		40.0		
Cetane Index		ASTM D4737	<40.0	56.4		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.004		
ppm Water	ppm	ASTM D6304	<500	41.1		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT





Laboratory Sample No. Lab Number Unique Number

: KT0000224 : 05769123

Received : 15 Feb 2023 Diagnosed : 20 Feb 2023

: 10338731 Diagnostician : Doug Bogart Test Package : DF-2 (Additional Tests: Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

4409 HWY 290E PAIGE, TX US 78659

Contact: J BAKALBAS jbakalbas@yahoo.com

Submitted By: SHANE OWEN

T:

F: