

PROBLEM SUMMARY

Sample Rating Trend


ISO

Machine Id KAESER AS 30T 6024838 (S/N 1003)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL	ATTENTION				
Particles >6µm	ASTM D7647	>1300	△ 3922	<u>^</u> 2258	<u>▲</u> 1849				
Particles >14μm	ASTM D7647	>80	<u> </u>	<u>^</u> 264	△ 107				
Particles >21µm	ASTM D7647	>20	<u></u> ▲ 82	<u>^</u> 64	<u>^</u> 23				
Particles >38μm	ASTM D7647	>4	<u>^</u> 6	<u>^</u> 6	0				
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u>^</u> 21/19/15	<u>^</u> 20/18/15	<u>▲</u> 18/14				

Customer Id: GLOCOR Sample No.: KC05775405 **Lab Number:** 05775405 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

07 Oct 2022 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



09 Jul 2021 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



26 Jan 2021 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AS 30T 6024838 (S/N 1003)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		Jul2017	Jul2018 Jul2019	Jul2020 Jul2021	Feb 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		KC05775405	KC05672864	KC05307250
Sample Date		Client Info		06 Feb 2023	07 Oct 2022	09 Jul 2021
Machine Age	hrs	Client Info		32810	30845	22510
Oil Age	hrs	Client Info		0	0	2991
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	6	23	5
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	31	0	8
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	51	19	40
Calcium	ppm	ASTM D5185m	2	2	0	3
Phosphorus	ppm	ASTM D5185m		<1	3	3
Zinc	ppm	ASTM D5185m		13	27	0
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		29	10	16
Potassium	ppm	ASTM D5185m	>20	2	0	2
Water	%	ASTM D6304	>0.05	0.014	0.013	0.025
ppm Water	ppm	ASTM D6304	>500	147.5	136.8	259.2
FLUID CLEANLIN	ESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		13810	6585	6966
Particles >6µm		ASTM D7647	>1300	4 3922	<u>^</u> 2258	▲ 1849
Particles >14μm		ASTM D7647	>80	<u>^</u> 271	<u>^</u> 264	1 07
Particles >21µm		ASTM D7647	>20	<u> 82</u>	△ 64	△ 23
Particles >38μm		ASTM D7647	>4	<u>^</u> 6	<u>^</u> 6	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	2 1/19/15	2 0/18/15	<u>▲</u> 18/14
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.36	0.331



OIL ANALYSIS REPORT



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: