

### **OIL ANALYSIS REPORT**

Sample Rating Trend

ISO

Machine Id

# KAESER BSD 60T 6399643 (S/N 1233)

Component Compressor

Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>ATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP49124	KCP38496	KCP00947
Sample Date		Client Info		27 Jan 2023	08 Mar 2022	26 Mar 2021
Machine Age	hrs	Client Info		16763	13664	10695
Oil Age	hrs	Client Info		3099	2969	3300
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		<1	1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		7	7	10
Tin	ppm	ASTM D5185m	>10	′ <1	1	0
Antimony	ppm	ASTM D5185m	~10	<1 		0
Vanadium		ASTM D5185m		0	0	0
	ppm			0	0	0
Cadmium	ppm	ASTM D5185m		U		-
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	2	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	38	47	27
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	8	6	2
Zinc	ppm	ASTM D5185m	0	21	21	56
Sulfur	ppm	ASTM D5185m	23500	19389	18080	18639
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	2
Sodium	ppm	ASTM D5185m		23	30	11
Potassium	ppm	ASTM D5185m	>20	8	7	7
Water	%	ASTM D6304	>0.05	0.026	0.029	0.019
ppm Water	ppm	ASTM D6304	>500	268.3	294.2	192.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		27243	23345	7235
Particles >6µm		ASTM D7647	>1300	<u> </u>	▲ 7114	<b>1</b> 964
Particles >14µm		ASTM D7647	>80	<u> </u>	<u> </u>	<b>2</b> 11
Particles >21µm		ASTM D7647	>20	<u> </u>	<b>A</b> 231	<b>1</b>
Particles >38µm		ASTM D7647	>4	4	2	4
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	▲ 20/17	▲ 18/15
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN) 33:09) Rev: 1	mg KOH/g	ASTM D8045	1.0	0.33 0.26 0.402 Contact/Location: C. HIMA - CHEFAIG		

Report Id: CHEFAIGA [WUSCAR] 05778239 (Generated: 04/06/2024 14:33:09) Rev: 1


Contact/Location: C. HIMA - CHEFAIGA





(maa)


Water

## **OIL ANALYSIS REPORT**












Bottom



 Test Package
 : IND 2 (Additional Tests: KF, PrtCount)

 To discuss this sample report, contact Customer Service at 1-800-237-1369.

Laboratory

Sample No.

Lab Number

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: CHEFAIGA [WUSCAR] 05778239 (Generated: 04/06/2024 14:33:09) Rev: 1

Contact/Location: C. HIMA - CHEFAIGA

Page 2 of 2

T:

F:

Contact: C. HIMA

chima@grupomedrano.com