


PROBLEM SUMMARY

Machine Id 7002955 (S/N 1223) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ATTENTION	ATTENTION	ABNORMAL		
Particles >6µm	ASTM D7647	>1300	<u> </u>	A 2152	5 491		
Particles >14µm	ASTM D7647	>80	<u> </u>	67	4 243		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>	🔺 20/18/13	2 0/15		


Customer Id: AMABALMAR Sample No.: KCP55191 Lab Number: 05781839 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 <u>angela.borella@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

03 Oct 2022 Diag: Doug Bogart

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

07 Apr 2022 Diag: Jonathan Hester

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

01 Nov 2021 Diag: Angela Borella

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





view report



OIL ANALYSIS REPORT

SAMPLE INCODMATION

Sample Rating Trend ISO

Machine Id 7002955 (S/N 1223) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP55191	KCP46934D	KCP44671
Sample Date		Client Info		22 Feb 2023	03 Oct 2022	07 Apr 2022
Machine Age	hrs	Client Info		13970	12521	10023
Oil Age	hrs	Client Info		1448	2498	0
Oil Changed		Client Info		Not Changd	Changed	Changed
Sample Status				ATTENTION	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	۰ <1	1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m		1	1	<1
Tin	ppm	ASTM D5185m	>10	، <1	0	0
Antimony	ppm	ASTM D5185m	~10			
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ррш			U		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	3
Barium	ppm	ASTM D5185m	90	7	0	6
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	62	44	32
Calcium	ppm	ASTM D5185m	0	<1	0	3
Phosphorus	ppm	ASTM D5185m	0	3	16	2
Zinc	ppm	ASTM D5185m	0	9	0	3
Sulfur	ppm	ASTM D5185m	23500	21777	23542	10491
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	1	1
Sodium	ppm	ASTM D5185m		16	12	8
Potassium	ppm	ASTM D5185m	>20	2	<1	0
Water	%	ASTM D6304	>0.05	0.036	0.021	0.021
ppm Water	ppm	ASTM D6304	>500	369.1	210.0	216.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4052	6125	24593
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u> </u>	4 5491
Particles >14µm		ASTM D7647	>80	<mark>/</mark> 97	67	4 243
Particles >21µm		ASTM D7647	>20	25	15	5 6
Particles >38µm		ASTM D7647	>4	1	0	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 19/18/14	▲ 20/18/13	▲ 20/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.34	0.31	0.36
0.00.06) Dour 1			Contract/			


Report Id: AMABALMAR [WUSCAR] 05781839 (Generated: 07/18/2023 09:38:36) Rev: 1


Contact/Location: SERVICE MANAGER - AMABALMAR



OIL ANALYSIS REPORT








Abnorma


40

35

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.5	46.2	45.9
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Color						



Bottom



Contact/Location: SERVICE MANAGER - AMABALMAR