




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
35169
 Component
Diesel Engine
 Fluid
NOT GIVEN (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is a moderate amount of particulates present in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KLM2339318	KLM2339355	KL0008568
Sample Date	Client Info		11 Feb 2023	03 Nov 2022	30 Jun 2022
Machine Age	mls	Client Info	21142	11198	1073
Oil Age	mls	Client Info	21142	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ATTENTION	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	20	10	17
Chromium	ppm	ASTM D5185m >20	1	<1	<1
Nickel	ppm	ASTM D5185m >4	0	<1	0
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m >3	0	1	<1
Aluminum	ppm	ASTM D5185m >20	8	2	4
Lead	ppm	ASTM D5185m >40	3	2	<1
Copper	ppm	ASTM D5185m >330	297	123	34
Tin	ppm	ASTM D5185m >15	1	1	2
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	41	93	115
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	54	51	4
Manganese	ppm	ASTM D5185m	2	<1	2
Magnesium	ppm	ASTM D5185m	1092	1086	708
Calcium	ppm	ASTM D5185m	1105	1174	1416
Phosphorus	ppm	ASTM D5185m	947	1027	726
Zinc	ppm	ASTM D5185m	1263	1280	809
Sulfur	ppm	ASTM D5185m	3178	3862	3935

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	5	3	5
Sodium	ppm	ASTM D5185m	2	<1	4
Potassium	ppm	ASTM D5185m >20	24	6	8
Fuel	%	ASTM D3524 >5	0.5	<1.0	0.3

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	0.5	0.2	0.1
Nitration	Abs/cm	*ASTM D7624 >20	9.6	7.5	7.6
Sulfation	Abs/.1mm	*ASTM D7415 >30	21.3	21.3	19.0



OIL ANALYSIS REPORT







FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		7586	670	---
Particles >6µm	ASTM D7647	>5000	4133	365	---
Particles >14µm	ASTM D7647	>640	▲ 703	62	---
Particles >21µm	ASTM D7647	>160	▲ 237	21	---
Particles >38µm	ASTM D7647	>40	37	3	---
Particles >71µm	ASTM D7647	>10	4	0	---
Oil Cleanliness	ISO 4406 (c)	>19/16	▲ 19/17	16/13	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414	>25	17.8	16.0	13.9
Base Number (BN)	mg KOH/g ASTM D2896		10.50	10.3	9.5

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual	>0.2	NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt ASTM D445		11.8	12.9	9.6

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KLM2339318 **Received** : 02 Mar 2023
Lab Number : **05782027** **Diagnosed** : 06 Mar 2023
Unique Number : 10361697 **Diagnostician** : Don Baldrige
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel, PrtCount)

CITY & COUNTY HONOLULU
 99-999 IWAENA RD
 AIEA, HI
 US 96701
 Contact: CLYDE OMIJA
 comija@honolulu.gov
 T: (575)623-9952
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)