



PROBLEM SUMMARY


Area
PAUL MORETZ [187416-N2STV4W]
 Machine Id
9013165
 Component
Hydraulic System
 Fluid
AW HYDRAULIC OIL ISO 46 (55 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Silicon (ppm)



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | ABNORMAL | --- | --- |
|---------------|-----|-------------|-----|----------|----------|----------|
| Silicon | ppm | ASTM D5185m | >15 | ▲ 46 | --- | --- |
| PrtFilter | | | | no image | no image | no image |

Customer Id: RGGYOR
 Sample No.: PH05782452
 Lab Number: 05782452
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS


There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Area
PAUL MORETZ [187416-N2STV4W]
 Machine Id
9013165
 Component
Hydraulic System
 Fluid
AW HYDRAULIC OIL ISO 46 (55 GAL)

DIAGNOSIS

▲ Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

| method | limit/base | current | history1 | history2 |
|---------------|-----------------|--------------------|----------|----------|
| Sample Number | Client Info | PH05782452 | --- | --- |
| Sample Date | Client Info | 20 Feb 2023 | --- | --- |
| Machine Age | hrs Client Info | 0 | --- | --- |
| Oil Age | hrs Client Info | 8 | --- | --- |
| Oil Changed | Client Info | N/A | --- | --- |
| Sample Status | | ABNORMAL | --- | --- |

WEAR METALS

| method | limit/base | current | history1 | history2 |
|--------------------------|------------|--------------|----------|----------|
| Iron ppm ASTM D5185m | >20 | 0 | --- | --- |
| Chromium ppm ASTM D5185m | >20 | 0 | --- | --- |
| Nickel ppm ASTM D5185m | >20 | <1 | --- | --- |
| Titanium ppm ASTM D5185m | | <1 | --- | --- |
| Silver ppm ASTM D5185m | | <1 | --- | --- |
| Aluminum ppm ASTM D5185m | >20 | <1 | --- | --- |
| Lead ppm ASTM D5185m | >20 | <1 | --- | --- |
| Copper ppm ASTM D5185m | >20 | 2 | --- | --- |
| Tin ppm ASTM D5185m | >20 | <1 | --- | --- |
| Vanadium ppm ASTM D5185m | | 0 | --- | --- |
| Cadmium ppm ASTM D5185m | | 0 | --- | --- |

ADDITIVES

| method | limit/base | current | history1 | history2 |
|----------------------------|------------|-------------|----------|----------|
| Boron ppm ASTM D5185m | 5 | 3 | --- | --- |
| Barium ppm ASTM D5185m | 5 | 1 | --- | --- |
| Molybdenum ppm ASTM D5185m | 5 | 4 | --- | --- |
| Manganese ppm ASTM D5185m | | 0 | --- | --- |
| Magnesium ppm ASTM D5185m | 25 | 18 | --- | --- |
| Calcium ppm ASTM D5185m | 200 | 100 | --- | --- |
| Phosphorus ppm ASTM D5185m | 300 | 342 | --- | --- |
| Zinc ppm ASTM D5185m | 370 | 435 | --- | --- |
| Sulfur ppm ASTM D5185m | 2500 | 1514 | --- | --- |

CONTAMINANTS

| method | limit/base | current | history1 | history2 |
|---------------------------|------------|--------------|----------|----------|
| Silicon ppm ASTM D5185m | >15 | ▲ 46 | --- | --- |
| Sodium ppm ASTM D5185m | | 0 | --- | --- |
| Potassium ppm ASTM D5185m | >20 | <1 | --- | --- |
| Water % ASTM D6304 | >0.05 | NEG | --- | --- |

FLUID CLEANLINESS

| method | limit/base | current | history1 | history2 |
|------------------------------|------------|-----------------|----------|----------|
| Particles >4µm ASTM D7647 | >640 | 487 | --- | --- |
| Particles >6µm ASTM D7647 | >160 | 85 | --- | --- |
| Particles >14µm ASTM D7647 | >10 | 9 | --- | --- |
| Particles >21µm ASTM D7647 | >3 | 3 | --- | --- |
| Particles >38µm ASTM D7647 | >3 | 0 | --- | --- |
| Particles >71µm ASTM D7647 | >3 | 0 | --- | --- |
| Oil Cleanliness ISO 4406 (c) | >16/14/10 | 16/14/10 | --- | --- |


FLUID DEGRADATION

| method | limit/base | current | history1 | history2 |
|--------------------------------------|------------|-------------|----------|----------|
| Acid Number (AN) mg KOH/g ASTM D8045 | 0.57 | 0.46 | --- | --- |




OIL ANALYSIS REPORT


▲ Silicon (ppm)




Particle Count




Particle Trend



Viscosity @ 40°C



Particle Trend







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|--------------|----------|
| White Metal | scalar | *Visual | NONE | NONE | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- |
| Silt | scalar | *Visual | NONE | NONE | --- |
| Debris | scalar | *Visual | NONE | NONE | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- |
| Odor | scalar | *Visual | NORML | NORML | --- |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | --- |
| Free Water | scalar | *Visual | | NEG | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|-------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 46 | 42.6 | --- | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

| | | | |
|-----------|----------|----------|----------|
| Color | | no image | no image |
| Bottom | | no image | no image |
| PrtFilter | no image | no image | no image |

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PH05782452 **Received** : 03 Mar 2023
Lab Number : **05782452** **Diagnosed** : 06 Mar 2023
Unique Number : 10362122 **Diagnostician** : Angela Borella
Test Package : PLANT (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

RG GROUP
 15 FLOUR MILL RD
 YORK, PA
 US 17406
 Contact: PAUL MORETZ
 paul.moretz@rg-group.com
 T: (717)849-0310
 F: