

FUEL REPORT

Sample Rating Trend



Machine Id SIMDIS 2

Component Diesel Fuel Fluid {not provided} (--- GAL)


DIAGNOSIS

			1	Mar2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC05784350		
Sample Date		Client Info		05 Mar 2023		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		184		
5% Distillation Point	°C	ASTM D86		200		
10% Distill Point	°C	ASTM D86		208		
15% Distillation Point	°C	ASTM D86		216		
20% Distill Point	°C	ASTM D86		223		
30% Distill Point	°C	ASTM D86		238		
40% Distill Point	°C	ASTM D86		252		
50% Distill Point	°C	ASTM D86		266		
60% Distill Point	°C	ASTM D86		282		
70% Distill Point	°C	ASTM D86		297		
80% Distill Point	°C	ASTM D86		313		
85% Distillation Point	°C	ASTM D86		323		
90% Distill Point	°C	ASTM D86		333		
95% Distillation Point	°C	ASTM D86		348		
Final Boiling Point	°C	ASTM D86		365		

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			no image	no image	no image
Bottom			no image	no image	no image



FUEL REPORT



Contact/Location: CHEVRON DEMO - WEACAR