

## **FUEL REPORT**

Sample Rating Trend

NORMAL



SIMDIS 3

Component

Diesel Fuel


Fluid

{not provided} (--- GAL)

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC05784351		
Sample Date		Client Info		05 Mar 2023		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		183		
5% Distillation Point	°C	ASTM D86		199		
10% Distill Point	°C	ASTM D86		207		
15% Distillation Point	°C	ASTM D86		215		
20% Distill Point	°C	ASTM D86		222		
30% Distill Point	°C	ASTM D86		237		
40% Distill Point	°C	ASTM D86		251		
50% Distill Point	°C	ASTM D86		265		
60% Distill Point	°C	ASTM D86		281		
70% Distill Point	°C	ASTM D86		296		
80% Distill Point	°C	ASTM D86		313		
85% Distillation Point	°C	ASTM D86		323		
90% Distill Point	°C	ASTM D86		333		
95% Distillation Point	°C	ASTM D86		347		
Final Boiling Point	°C	ASTM D86		361		
SAMPLE IMAGES	;	method	limit/base	current	history1	history2
Color				no image	no image	no image
Bottom				no image	no image	no image



## **FUEL REPORT**





Laboratory Sample No. Lab Number Unique Number

: 05784351

: 10364021

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC05784351

Received Diagnosed

: 02 Oct 2023 Diagnostician : System

: 06 Mar 2023

Test Package: DF-5 (Additional Tests: API, Cetane, FUEL, GCD, Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

**WEARCHECK USA** 

501 Madison Ave Cary, NC US 27513

F: (919)379-4050

Contact: CHEVRON DEMO jfazenbaker@nc.rr.com

T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)