


# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**ARIEL**  
Component  
**Reciprocating Compressor**  
Fluid  
**NOT GIVEN (--- GAL)**

**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

**Contamination**

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>TO70000055</b>	TO70000054	TO60000197
Sample Date	Client Info			<b>07 Mar 2023</b>	07 Feb 2023	01 Dec 2022
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>0</b>	0	0
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m		<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m	>25	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>50	<b>0</b>	0	0
Tin	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m		<b>2</b>	1	2
Calcium	ppm	ASTM D5185m		<b>41</b>	28	0
Phosphorus	ppm	ASTM D5185m		<b>36</b>	31	19
Zinc	ppm	ASTM D5185m		<b>7</b>	16	2
Sulfur	ppm	ASTM D5185m		<b>2533</b>	2600	3161

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>0</b>	3	2
Sodium	ppm	ASTM D5185m		<b>0</b>	0	0
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	<1	0
Water	%	ASTM D6304	>0.1	<b>0.006</b>	0.006	0.011
ppm Water	ppm	ASTM D6304	>1000	<b>62.4</b>	69.8	117.4

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>2784</b>	4792	3931
Particles >6µm		ASTM D7647	>2500	<b>464</b>	1158	932
Particles >14µm		ASTM D7647	>320	<b>11</b>	64	49
Particles >21µm		ASTM D7647	>80	<b>2</b>	11	8
Particles >38µm		ASTM D7647	>20	<b>1</b>	1	0
Particles >71µm		ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>19/16/11</b>	19/17/13	19/17/13

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.015</b>	0.015	0.028


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	206	208	207
Visc @ 100°C	cSt	ASTM D445	17.7	18.0	18.0
Viscosity Index (VI)	Scale	ASTM D2270	92	94	94

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO70000055 **Received** : 14 Mar 2023  
**Lab Number** : 05790914 **Diagnosed** : 16 Mar 2023  
**Unique Number** : 10375585 **Diagnostician** : Angela Borella  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**GARLAND RENEWABLES**  
 3175 ELM GROVE RD  
 ROWLETT, TX  
 US 75089  
 Contact: DUSTIN FRY  
 dustin@morrowrenew.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)