




PROBLEM SUMMARY

Sample Rating Trend






WEAR



Area
ContiTech USA_Lincoln
 Machine Id
#5 Calender Middle Roll
 Component
Gear Drive
 Fluid
MOBIL SHC 632 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. We advise that you inspect for the source(s) of wear. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	NORMAL	NORMAL
PQ		ASTM D8184	493	---	---
Iron	ppm	ASTM D5185m >150	599	149	45
Particles >4µm		ASTM D7647 >20000	269763	---	---
Particles >6µm		ASTM D7647 >5000	240628	---	---
Particles >14µm		ASTM D7647 >640	107798	---	---
Particles >21µm		ASTM D7647 >160	35701	---	---
Particles >38µm		ASTM D7647 >40	1665	---	---
Particles >71µm		ASTM D7647 >10	12	---	---
Oil Cleanliness		ISO 4406 (c) >21/19/16	25/25/24	---	---

Customer Id: CON4021LIN
 Sample No.: SBP0000553
 Lab Number: 05792026
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

HISTORICAL DIAGNOSIS

26 Apr 2021 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



03 Apr 2018 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
ContiTech USA_Lincoln
 Machine Id
#5 Calender Middle Roll
 Component
Gear Drive
 Fluid
MOBIL SHC 632 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. We advise that you inspect for the source(s) of wear. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

Moderate concentration of visible metal present. Gear wear is indicated.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		SBP0000553	SBP16367027	SBP08363011
Sample Date	Client Info		10 Mar 2023	26 Apr 2021	03 Apr 2018
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	Not Changd
Sample Status			SEVERE	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		493	---	---
Iron	ppm	ASTM D5185m >150	599	149	45
Chromium	ppm	ASTM D5185m >10	5	2	0
Nickel	ppm	ASTM D5185m >10	3	1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	1	0	0
Lead	ppm	ASTM D5185m >100	0	1	0
Copper	ppm	ASTM D5185m >50	7	4	0
Tin	ppm	ASTM D5185m >10	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<1	1	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	1	1	1
Manganese	ppm	ASTM D5185m	4	0	0
Magnesium	ppm	ASTM D5185m	2	0	0
Calcium	ppm	ASTM D5185m	3	3	0
Phosphorus	ppm	ASTM D5185m	311	338	317
Zinc	ppm	ASTM D5185m	31	18	3
Sulfur	ppm	ASTM D5185m	702	---	---

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	20	21	18
Sodium	ppm	ASTM D5185m	2	2	0
Potassium	ppm	ASTM D5185m >20	2	0	0
Chlorine	ppm	ASTM D5185m	---	0	0
Water	%	ASTM D6304 >0.1	0.005	0	0
ppm Water	ppm	ASTM D6304 >1000	51.9	---	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	269763	---	---
Particles >6µm	ASTM D7647	>5000	240628	---	---
Particles >14µm	ASTM D7647	>640	107798	---	---
Particles >21µm	ASTM D7647	>160	35701	---	---
Particles >38µm	ASTM D7647	>40	1665	---	---
Particles >71µm	ASTM D7647	>10	12	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	25/25/24	---	---



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37	0.41	0.42






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	MODER	---	---
Yellow Metal	scalar	*Visual	NONE	NONE	---	---
Precipitate	scalar	*Visual	NONE	NONE	---	---
Silt	scalar	*Visual	NONE	NONE	---	---
Debris	scalar	*Visual	NONE	LIGHT	---	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---	---
Appearance	scalar	*Visual	NORML	NORML	---	---
Odor	scalar	*Visual	NORML	NORML	---	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---	---
Free Water	scalar	*Visual		NEG	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	325.8	282	286.6	316.9

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : SBP0000553 **Received** : 15 Mar 2023
Lab Number : **05792026** **Diagnosed** : 19 Mar 2023
Unique Number : 10376697 **Diagnostician** : Doug Bogart
Test Package : PLANT

ContiTech USA Lincoln - 713784
 4021 N 56th St.
 Lincoln, NE
 US 68504
 Contact: Jeff Hartman
 jeff.hartman@continental.com
 T: (402)580-7630
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)